


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

BUCK_U2220 BUCK_U2220_M2220

Non-Drive End Pump

ROYAL PURPLE SYNFILM GT 46 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The water content is negligible. There is no indication of any contamination in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Mar2021 May2	2021 Aug2021 Dec2021 May	022 Jan2023 Jun2023 Nov2023 Feb	2024 Jun2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0032995	RP0031919	RP0031969
Sample Date		Client Info		07 Jun 2024	05 Feb 2024	20 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>90	2	1	4
Chromium	ppm	ASTM D5185m	>5	0	0	0
Nickel	ppm	ASTM D5185m	>5	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>3	0	0	0
Aluminum	ppm	ASTM D5185m	>7	0	0	<1
_ead	ppm	ASTM D5185m	>12	2	1	3
Copper	ppm	ASTM D5185m	>30	8	10	11
Tin	ppm	ASTM D5185m	>9	<1	2	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	95	87	74	97
Calcium	ppm	ASTM D5185m	0	6	0	3
Phosphorus	ppm	ASTM D5185m	0	4	0	4
Zinc	ppm	ASTM D5185m	0	8	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>60	2	<1	2
Sodium	ppm	ASTM D5185m		4	3	2
Potassium	ppm	ASTM D5185m	>20	3	0	2
Water	%	ASTM D6304	>.1	0.019	0.070	0.034
opm Water	ppm	ASTM D6304	>1000	199	705	345
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.41	0.35	0.52
VICLIAL						
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
White Metal Yellow Metal	scalar	*Visual	NONE NONE	NONE NONE	NONE NONE	NONE NONE
White Metal Yellow Metal Precipitate	scalar scalar	*Visual *Visual *Visual	NONE NONE	NONE NONE	NONE NONE NONE	NONE NONE NONE
White Metal Yellow Metal Precipitate	scalar	*Visual *Visual *Visual *Visual	NONE NONE	NONE NONE	NONE NONE	NONE NONE
White Metal Yellow Metal Precipitate Silt	scalar scalar	*Visual *Visual *Visual	NONE NONE	NONE NONE	NONE NONE NONE	NONE NONE NONE
White Metal Yellow Metal Precipitate Silt Debris	scalar scalar scalar	*Visual *Visual *Visual *Visual	NONE NONE NONE	NONE NONE NONE	NONE NONE NONE	NONE NONE NONE
White Metal Yellow Metal Precipitate Silt Debris Sand/Dirt	scalar scalar scalar scalar	*Visual *Visual *Visual *Visual *Visual	NONE NONE NONE NONE	NONE NONE NONE NONE	NONE NONE NONE NONE	NONE NONE NONE NONE LIGHT
White Metal Yellow Metal Precipitate Silt Debris Sand/Dirt Appearance	scalar scalar scalar scalar scalar	*Visual *Visual *Visual *Visual *Visual *Visual	NONE NONE NONE NONE NONE	NONE NONE NONE NONE NONE	NONE NONE NONE NONE NONE	NONE NONE NONE LIGHT NONE
White Metal Yellow Metal Precipitate Silt Debris Sand/Dirt Appearance Odor Emulsified Water	scalar scalar scalar scalar scalar scalar	*Visual *Visual *Visual *Visual *Visual *Visual *Visual *Visual	NONE NONE NONE NONE NONE NONE NONE NORML	NONE NONE NONE NONE NONE NONE NONE	NONE NONE NONE NONE NONE NONE NONE	NONE NONE NONE NONE LIGHT NONE NORML NORML NEG



OIL ANALYSIS REPORT












GRAPHS Ferrous Alloys











Certificate 12367

Laboratory Sample No.

: RP0032995 Lab Number : 06205590 Unique Number : 11073051

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 10 Jun 2024

Tested : 13 Jun 2024 Diagnosed : 13 Jun 2024 - Angela Borella

ENERGY TRANSFER - BUCKS MT. EYRE AND DOLINGTON ROAD

WAKEFIELD, PA US 18940

Contact: QUITA MORGAN

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (610)220-8386

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: ENEWAK [WUSCAR] 06205590 (Generated: 06/14/2024 03:35:34) Rev: 1

Submitted By: ADAM HUMMEL

F: