

# **OIL ANALYSIS REPORT**

Sample Rating Trend





# CHEMLUBE 630 [1680731] L5-ML-BML-SPRL5 - PFNONWOVENS

Gearbox

#### DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil

# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Mar2024		
SAMPLE INFORM	<i>I</i> ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06205624		
Sample Date		Client Info		19 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	10		
Chromium	ppm	ASTM D5185m	>15	<1		
Nickel	ppm	ASTM D5185m	>15	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>100	3		
Copper	ppm	ASTM D5185m	>200	4		
Tin	ppm	ASTM D5185m	>25	1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	3.1	5		
Barium	ppm	ASTM D5185m	0.1	0		
Molybdenum	ppm	ASTM D5185m	0	2		
Manganese	ppm	ASTM D5185m	0.7	2		
Magnesium	ppm	ASTM D5185m	0	<1		
Calcium	ppm	ASTM D5185m	0	5		
Phosphorus	ppm	ASTM D5185m	1642	775		
Zinc	ppm	ASTM D5185m	0	5		
Sulfur	ppm	ASTM D5185m	377	8459		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	5		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2


Acid Number (AN)

mg KOH/g ASTM D8045 0.154

0.45




# **OIL ANALYSIS REPORT**





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
<b>Emulsified Water</b>	scalar	*Visual	>0.2	NEG		
Free Water	scalar	*Visual		NEG		
	150					
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	141.9	214		
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color					no image	no image


## **GRAPHS**

**Bottom** 









no image

no image





Certificate 12367

Laboratory Sample No.

Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Lab Number : 06205624

: UCH06205624 Unique Number : 11073085

To discuss this sample report, contact Customer Service at 1-800-237-1369.

Received : 10 Jun 2024 **Tested** 

: 13 Jun 2024 Diagnosed : 13 Jun 2024 - Sean Felton

**CORROSION PRODUCTS & EQUIPMENT** 

940 POINTVIEW AVE EPHRATA, PA

T: (717)961-1998

US 17522 Contact: RYAN HUNGARTER rhungarter@corrosion-products.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: UCPROWES [WUSCAR] 06205624 (Generated: 06/14/2024 02:21:37) Rev: 1

Contact/Location: RYAN HUNGARTER - UCPROWES