

## **OIL ANALYSIS REPORT**

Sample Rating Trend



## Area **PACO 68 [1603836]** L7-ML-BMB-SCH - PFNONWOVENS Component Gearbox

#### Recommendation

Resample at the next service interval to monitor.

## Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

## Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06205627		
Sample Date		Client Info		26 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	4		
Chromium	ppm	ASTM D5185m	>15	<1		
Nickel	ppm	ASTM D5185m	>15	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>100	3		
Copper	ppm	ASTM D5185m	>200	6		
Tin	ppm	ASTM D5185m	>25	1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		3		
Manganese	ppm	ASTM D5185m		2		
Magnesium	ppm	ASTM D5185m		5		
Calcium	ppm	ASTM D5185m		109		
Phosphorus	ppm	ASTM D5185m		440		
Zinc	ppm	ASTM D5185m		591		
Sulfur	ppm	ASTM D5185m		7405		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	3		
Sodium	ppm	ASTM D5185m		4		
Potassium	ppm	ASTM D5185m	>20	6		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.88		



# **OIL ANALYSIS REPORT**

VISUAL



							riistoi yz
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Mar26/24	Appearance	scalar	*Visual	NORML	NORML		
Marź	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.2	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPER	TIES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		59.0		
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
		.0	method	initit/base	current	history	THStory Z
Mar26/24 +	Color				•	no image	no image
	Bottom					no image	no image
	Non-ferrous Meta	ıls		Mar26/24 - Mar26/24	Acid Number		
	100 50 50 50 50 50 50 50 50 50 50 50 50 5			Mar26/24	1.6 1.4 1.2 1.0 4 7 2 9 2 8 2 8 2 8 2 8 2 8 2 8 2 8 2 8 2 8		ACCC-14
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report Denotes test methods that atements of conformity to s	: 11073088 : IND 2 t, contact Customer Serv t are outside of the ISO 3	Rece Teste Diagr vice at 1-8 17025 sco	ived : 10 ed : 13 nosed : 13 800-237-1369 ope of accrea	) Jun 2024 3 Jun 2024 Jun 2024 - S 9. 1/itation.	ean Felton rhung	Contact: RYAN arter@corrosion T:	DINTVIEW AVI EPHRATA, PA US 1752 HUNGARTEI

Contact/Location: RYAN HUNGARTER - UCPROWES