


FUEL REPORT

Machine Id

KIOTI NS4710HB VX1B-00175

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)



DIAGNOSIS

Recommendation

We advise that you filter this fluid before use.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. The water content is negligible.


Fuel Condition

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel (US EPA/CGSB-3.517-3 type B). Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

R) (GAL)			,	Jun 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KT0001563		
Sample Date		Client Info		04 Jun 2024		
Machine Age	hrs	Client Info		699		
Sample Status				ABNORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	3.0	2.66		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	65.3		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0		
Sulfur (UVF)	ppm	ASTM D5453		10		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	178		
5% Distillation Point	°C	ASTM D86		197		
10% Distill Point	°C	ASTM D86	201	207		
15% Distillation Point	°C	ASTM D86		214		
20% Distill Point	°C	ASTM D86	216	222		
30% Distill Point	°C	ASTM D86	230	238		
40% Distill Point	°C	ASTM D86	243	252		
50% Distill Point	°C	ASTM D86	255	266		
60% Distill Point	°C	ASTM D86	267	282		
70% Distill Point	°C	ASTM D86	280	297		
80% Distill Point	°C	ASTM D86	295	313		
85% Distillation Point	°C	ASTM D86		324		
90% Distill Point	°C	ASTM D86	310	334		
95% Distillation Point	°C	ASTM D86		351		
Final Boiling Point	°C	ASTM D86	341	365		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	36		
Cetane Index		ASTM D4737	<40.0	49		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1		
Sodium	ppm	ASTM D5185m	<0.1	1		
Potassium	ppm	ASTM D5185m	< 0.1	1		
Water	%	ASTM D6304	< 0.05	0.002		
ppm Water	ppm	ASTM D6304	< 500	24		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	1.7		



FUEL REPORT







Certificate 12367

Sample No.

Lab Number

: KT0001563 : 06206044 Unique Number : 11073505

Diagnosed Test Package : DF-2 (Additional Tests: Fuel, Screen)

Tested

: 18 Jun 2024

: 18 Jun 2024 - Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

560 S PINE ST MAXWELL, NE US 69151

Contact: Service Manager tt.millerrepair@yahoo.com T: (308)582-4303