


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 8428985

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

			Oct2023	May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC130631	KC05986490	
Sample Date		Client Info		06 May 2024	09 Oct 2023	
Machine Age	hrs	Client Info		4956	2261	
Oil Age	hrs	Client Info		2695	0	
Oil Changed		Client Info		Not Changd	N/A	
Sample Status				ABNORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	10	11	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	5	26	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		<1	2	
Zinc	ppm	ASTM D5185m		20	8	
CONTAMINANTS	}	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		5	8	
Potassium	ppm	ASTM D5185m	>20	2	14	
Water	%	ASTM D6304	>0.05	0.005	0.013	
ppm Water	ppm	ASTM D6304	>500	58	131.8	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			4202	
Particles >6μm		ASTM D7647	>1300		1158	
Particles >14μm		ASTM D7647	>80		114	
Particles >21µm		ASTM D7647	>20		3 6	
Particles >38µm		ASTM D7647	>4		1	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		19/17/14	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
		mounoa	III III Dasc	Current	Thistory i	Thistory 2

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.33

0.32



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: KC130631 **Lab Number** : 06206502 Unique Number : 11073963 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received : 11 Jun 2024 **Tested** : 13 Jun 2024 Diagnosed

: 13 Jun 2024 - Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

PACKAGING CORP OF AMERICA

15600 NW 15TH AVE M MIAMI, FL

US 33169 Contact: GLEN RUFFALO

glenruffalo@packagingcorp.com T:

F: Contact/Location: GLEN RUFFALO - PACMIAFL