


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER ASD 30T 3323198 (S/N 1231)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

#### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil.


#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		0ct2020	) Jan 2022	Feb 2023 Ma	y2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016228	KCPA000160	KCP34727
Sample Date		Client Info		07 May 2024	28 Feb 2023	10 Jan 2022
Machine Age	hrs	Client Info		58056	50895	42481
Oil Age	hrs	Client Info		7161	0	0
Oil Changed		Client Info		Changed	N/A	N/A
Sample Status				ATTENTION	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	18	13	7
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	2	5
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	41	32	73
Calcium	ppm	ASTM D5185m	2	0	<1	<1
Phosphorus	ppm	ASTM D5185m		2	14	8
Zinc	ppm	ASTM D5185m		19	18	7
Sulfur	ppm	ASTM D5185m		19780	15822	18591
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	2	2
Sodium	ppm	ASTM D5185m		18	12	28
Potassium	ppm	ASTM D5185m	>20	2	4	3
Water	%	ASTM D6304	>0.05	0.016	0.017	0.018
ppm Water	ppm	ASTM D6304	>500	167	175.0	182.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1707	11044	10367
Particles >6µm		ASTM D7647	>1300	589	<b>△</b> 3507	<b>△</b> 3869
Particles >14µm		ASTM D7647	>80	94	<u>222</u>	<b>△</b> 590
Particles >21µm		ASTM D7647	>20	<b>26</b>	<b>△</b> 32	<u></u> 148
Particles >38μm		ASTM D7647	>4	1	1	<u> </u>
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>18/16/14</b>	<b>△</b> 21/19/15	<b>△</b> 19/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No. Lab Number

: KCPA016228 : 06206510 Unique Number : 11073971

Received : 11 Jun 2024 **Tested** : 13 Jun 2024

Diagnosed : 13 Jun 2024 - Don Baldridge Test Package : IND 2 ( Additional Tests: KF, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1450 MS-6

US 38606

T:

F:

BATESVILLE, MS

Contact: Service Manager