


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER CSD 75T 4101487 (S/N 1193)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	0c2019 0c2020 Me2024					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA016040	KCP31393	KCP17368
Sample Date		Client Info		06 May 2024	22 Oct 2020	10 Oct 2019
Machine Age	hrs	Client Info		24658	18452	14396
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	<1	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	<1	10	8
Tin	ppm	ASTM D5185m	>10	0	<1	<1
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	0
Barium	ppm	ASTM D5185m	90	37	0	0
Molybdenum	ppm	ASTM D5185m		0	0	<1
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	73	39	11
Calcium	ppm	ASTM D5185m	2	<1	0	0
Phosphorus	ppm	ASTM D5185m		1	4	<1
Zinc	ppm	ASTM D5185m		3	13	24
Sulfur	ppm	ASTM D5185m		20464	18969	11727
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	3	4
Sodium	ppm	ASTM D5185m		25	12	19
Potassium	ppm	ASTM D5185m	>20	3	3	4
Water	%	ASTM D6304	>0.05	0.030	0.019	0.014
ppm Water	ppm	ASTM D6304	>500	305	193.0	149.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1181	1377	1646
Particles >6µm		ASTM D7647	>1300	186	382	218
Particles >14µm		ASTM D7647	>80	13	22	11
Particles >21µm		ASTM D7647	>20	4	4	2
Particles >38μm		ASTM D7647	>4	0	0	0
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/11	16/12	15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number : 06206517 Unique Number : 11073978

: KCPA016040 Received : 11 Jun 2024 **Tested** : 13 Jun 2024

Diagnosed

: 13 Jun 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1450 MS-6

US 38606

T:

F:

BATESVILLE, MS

Contact: Service Manager