

OIL ANALYSIS REPORT

Sample Rating Trend ISO

Machine Id

KAESER CSD 60T 1845500 (S/N 1004)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017737		
Sample Date		Client Info		24 May 2024		
Machine Age	hrs	Client Info		16385		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron Chromium	ppm	ASTM D5185m	>50 >10	<1 0		
Nickel	ppm	ASTM D5185m ASTM D5185m	>10	0		
Titanium	ppm		>3	0		
Silver	ppm	ASTM D5185m ASTM D5185m	>3	0		
	ppm			0		
Aluminum Lead	ppm	ASTM D5185m ASTM D5185m	>10	0		
	ppm			14		
Copper Tin	ppm	ASTM D5185m ASTM D5185m	>50			
Vanadium	ppm	ASTM D5185m	>10	0		
	ppm			-		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	90	25		
Calcium	ppm	ASTM D5185m	2	0		
Phosphorus	ppm	ASTM D5185m		3		
Zinc	ppm	ASTM D5185m		36		
Sulfur	ppm	ASTM D5185m		18891		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		7		
Potassium	ppm	ASTM D5185m	>20	7		
Water	%	ASTM D6304	>0.05	0.015		
ppm Water	ppm	ASTM D6304	>500	159		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		40300		
Particles >6µm		ASTM D7647	>1300	13045		
Particles >14µm		ASTM D7647	>80	<u> </u>		
Particles >21µm		ASTM D7647	>20	<u>^</u> 291		
Particles >38µm		ASTM D7647	>4	<u>^</u> 5		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 23/21/17		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
				Carrone		otor j.E

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.38



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: KCPA017737 Lab Number : 06206533 Unique Number : 11073994

Received **Tested** Diagnosed

: 11 Jun 2024 : 13 Jun 2024 Test Package : IND 2 (Additional Tests: KF, PrtCount)

: 13 Jun 2024 - Don Baldridge

US 21224 Contact: DONALD LOWELL donald.lowell@lehighhanson.com T:

3100 MERTENS AVE

BALTIMORE, MD

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: