

# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# FRICK SEAGUY C-11 (S/N 150243NFMFTHBA3)

Refrigeration Compressor

FRICK COMPRESSOR OIL #9 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		y2007 Aug20	08 Apr2010 Oct2011	Jun2013 Jan2015 Aug2018 /	Apr2022	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0013444	USP0001136	USP246379
Sample Date		Client Info		02 Jun 2024	15 Oct 2023	16 Mar 2023
Machine Age	hrs	Client Info		32995	0	32068
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	2	2	<1
Chromium	ppm	ASTM D5185m	>2	<1	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	<1
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	<1	0
Tin	ppm	ASTM D5185m	>4	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		<1	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	0	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m		0	0	2
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	1	0
Sodium	ppm	ASTM D5185m		0	0	<1
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.01	0.002	0.001	0.003
ppm Water	ppm	ASTM D6304		16	14.1	32.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	9580	<u>^</u> 22109	3298
Particles >6µm		ASTM D7647	>2500	1008	1419	460
Particles >14µm		ASTM D7647	>320	13	24	9
Particles >21µm		ASTM D7647	>80	2	7	1
Particles >38µm		ASTM D7647	>20	0	0	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	20/17/11	<u>^</u> 22/18/12	19/16/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974		0.015	0.011	0.014





## **OIL ANALYSIS REPORT**



4μm	1				
**************************************	m				- 1
-	7			1	
Abnormal				1	A II
				A	MI
				11	
Abnormal			A		
				LA	$\triangle \nabla$
May2/07 Aug28/08	Apr.13/10	m	an 8/15	00	2







VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.01	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
ELLIIN DRODERT	TIFC	mothod	limit/basa	current	history1	history?

I LOID I HOI LITT	ILO					
Visc @ 40°C	cSt	ASTM D445	64.0	66.9	66.0	66.2

SAMPLE IMAGES

Color

**Bottom** 


**GRAPHS** 
























Certificate 12367

Laboratory Sample No.

Lab Number : 06206586

: USP0013444 Unique Number : 11074047

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 11 Jun 2024 **Tested** : 14 Jun 2024

Diagnosed : 14 Jun 2024 - Doug Bogart **SEABOARD FOODS** 2700 ne 28th street

GUYMON, OK US 73942

Contact: SERGIO CARLOS

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (580)338-9613

F: