


# **OIL ANALYSIS REPORT**

## Sample Rating Trend









# Grand River CAT 1 GRRM01BE

Biogas Engine

CHEVRON HDAX 9500 GAS ENGINE OIL 40 (90 GAL)

## DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil


### **Fluid Condition**


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0934189	WC0934197	WC0934188
Sample Date		Client Info		07 Jun 2024	28 May 2024	17 May 2024
Machine Age	hrs	Client Info		73154	73032	72769
Oil Age	hrs	Client Info		596	474	211
Oil Changed	1110	Client Info		Not Changd	Not Changd	Not Changd
Sample Status		Oliciti IIIIo		NORMAL	NORMAL	NORMAL
CONTAMINATION		method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>.11	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	2	0	2
Chromium	ppm	ASTM D5185m		- <1	0	<1
Nickel	ppm	ASTM D5185m	<i>-</i> 1	0	0	<1
Titanium	ppm	ASTM D5185m		<1	0	<1
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	<b>~</b> 6	2	1	2
Lead		ASTM D5185m	>9	<1	0	1
	ppm			1	<1	3
Copper Tin	ppm	ASTM D5185m		-	<1	2
	ppm	ASTM D5185m	>4	<1 0		
Vanadium	ppm	ASTM D5185m		-	0	<1
	ppm	ASTM D5185m		<1	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		9	10	14
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		3	2	4
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m		14	15	14
Calcium	ppm	ASTM D5185m		1745	1733	1682
Phosphorus	ppm	ASTM D5185m		273	295	302
Zinc	ppm	ASTM D5185m		351	341	343
Sulfur	ppm	ASTM D5185m		1954	2013	2168
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>181	30	27	24
Sodium	ppm	ASTM D5185m	>21	0	<1	0
Potassium	ppm	ASTM D5185m	>20	2	0	3
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0	0
3001 /6				0.0	6.5	5.7
	Abs/cm	*ASTM D7624		6.8	0.5	5.7
	Abs/cm Abs/.1mm	*ASTM D7624 *ASTM D7415		16.2	15.8	15.1
Nitration	Abs/.1mm		limit/base			
Nitration Sulfation FLUID DEGRADAT	Abs/.1mm	*ASTM D7415	limit/base	16.2	15.8	15.1
Nitration Sulfation FLUID DEGRADAT Oxidation	Abs/.1mm	*ASTM D7415 method	limit/base	16.2 current	15.8 history1	15.1 history2
Nitration Sulfation FLUID DEGRADAT Oxidation Acid Number (AN)	Abs/.1mm FION Abs/.1mm	*ASTM D7415 method *ASTM D7414		16.2 current 11.4	15.8 history1 10.7	15.1 history2 8.9




## **OIL ANALYSIS REPORT**











VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>.11	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG


FLUID PROPER	IIIES	method			history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.7	13.5	13.3


Lead (ppm)


Abno	ormal				11222		11 111
0+							
5-			$\sim$				~^
20		<u>~</u>	23	<b>V</b>	F	<u>ب</u>	
Aug15/2	Nov10/2	Jan3/2	Mar7/2	May30/2	0ct23/23	Jec15/23	Apr17/24
		,		Š	0	ă	A


















Certificate 12367

Laboratory Sample No.

: WC0934189 Lab Number : 06206739 Unique Number : 11074200

Test Package : MOB 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

**Tested** Diagnosed

: 11 Jun 2024 : 13 Jun 2024 : 13 Jun 2024 - Sean Felton

**EDL NA Recips-Grand River** Grand River Powerstation, 8550 West Grand River Hwy Grand Ledge, MI US 48837

Contact: JAMES ALEXANDER james.alexander@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: