OIL ANALYSIS REPORT

Sample Rating Trend



WEAR

Machine Id
SJNM01BE
Component
Biogas Engine
Fluid
CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

DIAGNOSIS

Recommendation
No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear
The tin level is abnormal.

Contamination
There is no indication of any contamination in the oil.

Fluid Condition
The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**WC0865735**	WC0865693	WC0865716
Sample Date		Client Info		**07 Jun 2024**	30 May 2024	09 May 2024
Machine Age	hrs	Client Info		**72865**	72756	116074
Oil Age	hrs	Client Info		**567**	458	116074
Oil Changed		Client Info		**Not Changd**	Not Changd	Changed
Sample Status				**ABNORMAL**	NORMAL	SEVERE

CONTAMINATION		method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	**<1.0**	<1.0	<1.0
Water		WC Method		**NEG**	NEG	NEG
Glycol		WC Method		**NEG**	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>14	**3**	0	4
Chromium	ppm	ASTM D5185m	>3	**<1**	0	<1
Nickel	ppm	ASTM D5185m		**<1**	0	<1
Titanium	ppm	ASTM D5185m		**<1**	0	<1
Silver	ppm	ASTM D5185m		**0**	0	0
Aluminum	ppm	ASTM D5185m	>5	**2**	2	2
Lead	ppm	ASTM D5185m	>8	**3**	2	4
Copper	ppm	ASTM D5185m	>5	**2**	<1	2
Tin	ppm	ASTM D5185m	>3	▲ **3**	2	▲ 5
Vanadium	ppm	ASTM D5185m		**0**	0	<1
Cadmium	ppm	ASTM D5185m		**<1**	0	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**<1**	0	2
Barium	ppm	ASTM D5185m		**0**	0	1
Molybdenum	ppm	ASTM D5185m		**4**	3	6
Manganese	ppm	ASTM D5185m		**<1**	<1	<1
Magnesium	ppm	ASTM D5185m		**17**	18	26
Calcium	ppm	ASTM D5185m		**2054**	2034	2262
Phosphorus	ppm	ASTM D5185m		**299**	303	394
Zinc	ppm	ASTM D5185m		**393**	378	435
Sulfur	ppm	ASTM D5185m		**2422**	2174	2893

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>180	**157**	135	▲ 213
Sodium	ppm	ASTM D5185m	>20	**0**	0	0
Potassium	ppm	ASTM D5185m	>20	**2**	0	3

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		**0.1**	0.1	0.1
Nitration	Abs/cm	*ASTM D7624		**7.8**	7.5	8.1
Sulfation	Abs/.1mm	*ASTM D7415		**21.9**	21.2	23.4

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414		**18.6**	17.0	20.9
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	**1.49**	1.57	1.69
Base Number (BN)	mg KOH/g	ASTM D2896	5.4	**4.03**	3.97	3.98

OIL ANALYSIS REPORT

Non-ferrous Metals



FT-IR (Direct Trend)



Acid Number



Base Number



Viscosity @ 100°C



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	**NORML**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual		**NEG**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	**14.1**	14.0	14.4

GRAPHS

Iron (ppm)



Lead (ppm)



Aluminum (ppm)



Chromium (ppm)



Copper (ppm)



Silicon (ppm)



Viscosity @ 100°C



Base Number



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0865735
Lab Number : 06206740
Unique Number : 11074201
Test Package : MOB 2

Received : 11 Jun 2024
Tested : 13 Jun 2024
Diagnosed : 13 Jun 2024 - Sean Felton

Certificate L2367

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

EDL NA Recips-South Jordan
South Jordan Powerstation, 10473 S. Bacchus Hwy.
South Jordan, UT
US 84095
Contact: Aaron Klein
aaron.klein@edlenergy.com
T:
F: