




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area
Thompson Falls
 Machine Id
THF01 Governor

Component
Case Drain Governor System

Fluid
LUBRICATION ENG 6802 MULTEC IND OIL 46 (40 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | WC0757781 | WC0757772 | WCI2326099 |
| Sample Date | Client Info | | 23 Apr 2024 | 10 Aug 2023 | 12 Oct 2022 |
| Machine Age | yrs | Client Info | 23 | 22 | 21 |
| Oil Age | yrs | Client Info | 17 | 16 | 15 |
| Oil Changed | Client Info | | Filtered | Filtered | Not Chngd |
| Sample Status | | | NORMAL | ABNORMAL | NORMAL |

CONTAMINATION

| | method | limit/base | current | history1 | history2 |
|-------|-----------|------------|------------|----------|----------|
| Water | WC Method | >0.1 | NEG | NEG | NEG |

WEAR METALS

| | method | limit/base | current | history1 | history2 | |
|----------|--------|-------------|---------|--------------|----------|----|
| Iron | ppm | ASTM D5185m | >50 | 2 | 1 | 2 |
| Chromium | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >10 | 0 | 0 | 0 |
| Titanium | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Silver | ppm | ASTM D5185m | | 0 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m | >3 | 0 | 0 | <1 |
| Lead | ppm | ASTM D5185m | >75 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m | >15 | <1 | <1 | <1 |
| Tin | ppm | ASTM D5185m | >55 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 | |
|------------|--------|-------------|---------|--------------|----------|------|
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | 0 | 0 | 1 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m | | <1 | <1 | 1 |
| Calcium | ppm | ASTM D5185m | | 141 | 112 | 121 |
| Phosphorus | ppm | ASTM D5185m | | 327 | 324 | 319 |
| Zinc | ppm | ASTM D5185m | | 195 | 181 | 201 |
| Sulfur | ppm | ASTM D5185m | | 1052 | 1025 | 1077 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 | |
|-----------|--------|-------------|---------|--------------|----------|---|
| Silicon | ppm | ASTM D5185m | >8 | <1 | 0 | 0 |
| Sodium | ppm | ASTM D5185m | | 5 | 5 | 3 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | 1 |

FLUID CLEANLINESS





| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-----------------|------------|----------|
| Particles >4µm | ASTM D7647 | >2500 | 2415 | ▲ 7087 | 387 |
| Particles >6µm | ASTM D7647 | >640 | 529 | ● 648 | 78 |
| Particles >14µm | ASTM D7647 | >80 | 22 | 13 | 8 |
| Particles >21µm | ASTM D7647 | >20 | 4 | 4 | 3 |
| Particles >38µm | ASTM D7647 | >4 | 0 | 0 | 0 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >18/16/13 | 18/16/12 | ▲ 20/17/11 | 16/13/10 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|------------|--------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.216 | 0.196 | 0.18 |




OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.1 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 46.06 | 46.4 | 46.6 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0757781 **Received** : 11 Jun 2024
Lab Number : 06207067 **Tested** : 13 Jun 2024
Unique Number : 11074528 **Diagnosed** : 13 Jun 2024 - Angela Borella
Test Package : IND 2 (Additional Tests: PrtCount)

NORTHWESTERN ENERGY
 6700 RAINBOW DAM RD
 GREAT FALLS, MT
 US 59404
 Contact: BRIAN WARD
 brian.ward@northwestern.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)