


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER ASD 25 4483692 (S/N 1095)

Compressor

KAESER SIGMA (OEM) S-460 (--- LTR)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb2015	Dec2015 Nov2021	Feb2023 Nov2023	Jun 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018449	KCPA010768	KCP46374
Sample Date		Client Info		04 Jun 2024	20 Nov 2023	22 Feb 2023
Machine Age	hrs	Client Info		49050	46937	43840
Oil Age	hrs	Client Info		5210	0	5720
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	<1	0
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	8	8	9
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	1	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	0	4	0
Calcium	ppm	ASTM D5185m	2	0	2	0
Phosphorus	ppm	ASTM D5185m		2	3	0
Zinc	ppm	ASTM D5185m		<1	0	0
Sulfur	ppm	ASTM D5185m		18968	21226	16363
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	1
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	0	1	0
Water	%	ASTM D6304	>0.05	0.007	△ 0.138	0.006
ppm Water	ppm	ASTM D6304	>500	78	<u> </u>	64.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9227		7338
Particles >6µm		ASTM D7647	>1300	4 3490		1694
Particles >14μm		ASTM D7647	>80	421		142
Particles >21µm		ASTM D7647	>20	<u> </u>		40
Particles >38µm		ASTM D7647	>4	<u> </u>		2
Particles >71μm		ASTM D7647	>3	1		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/19/16		20/18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: KCPA018449 Lab Number : 06207087 Unique Number : 11074548

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 11 Jun 2024 **Tested** : 13 Jun 2024

Diagnosed

: 13 Jun 2024 - Angela Borella

4461 BUSINESS DR SHINGLE SPRINGS, CA US 95682 Contact:

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: FMCSHI [WUSCAR] 06207087 (Generated: 06/15/2024 08:44:25) Rev: 1

T:

F: