


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 7116025

Component Compressor

KAESER SIGMA (OEM) M-460 (--- LTR)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		1		Jun 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Cample Number		Client Info		KCPA017722		
Sample Number Sample Date		Client Info		04 Jun 2024		
Machine Age	hrs	Client Info		27235		
Oil Age	hrs	Client Info		6000		
Oil Changed	1113	Client Info		Changed		
Sample Status		Ollerit IIIIO		ABNORMAL		
				ADNOMNAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<1		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	5		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	226		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	100	16		
Calcium	ppm	ASTM D5185m	0	14		
Phosphorus	ppm	ASTM D5185m	0	6		
Zinc	ppm	ASTM D5185m	0	34		
Sulfur	ppm	ASTM D5185m	23500	4718		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		60		
Potassium	ppm	ASTM D5185m	>20	13		
Water	%	ASTM D6304	>0.05	△ 0.331		
ppm Water	ppm	ASTM D6304	>500	▲ 3318		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		89006		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	1315		
Particles >21µm		ASTM D7647	>20	451		
Particles >38µm		ASTM D7647	>4	<u> </u>		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	24/21/18		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A -! -! Ni I (ANI)		AOTA DOO45	1.0	0.40		


Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.48



OIL ANALYSIS REPORT







Certificate 12367

Laboratory

Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA017722 Lab Number : 06207091 Unique Number : 11074552

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Received : 11 Jun 2024 **Tested** Diagnosed

: 13 Jun 2024 : 13 Jun 2024 - Angela Borella

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

REPUBLIC SERVICES INC

6025 BYASSEE DR HAZELWOOD, MO US 63042

Contact: A. HALL ahall3@republicservices.com

T: F: