



# FUEL REPORT

Sample Rating Trend



ISO



Machine Id  
**KIOTI CX2510HCB PX3DA0387**  
 Component  
**Diesel Fuel**  
 Fluid  
**DIESEL FUEL No. 2 (--- GAL)**

## DIAGNOSIS

### Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is a high amount of particulates present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KT0001568</b>	---	---
Sample Date	Client Info	<b>04 Jun 2024</b>	---	---
Machine Age	hrs Client Info	<b>32</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## PHYSICAL PROPERTIES

method	limit/base	current	history1	history2
Fuel Color	text *Visual Screen	<b>Yellow</b>	---	---
ASTM Color	scalar *ASTM D1500	<b>L2.5</b>	---	---
Pensky-Martens Flash Point	°C *PMCC Calculated	<b>60.2</b>	---	---

## SULFUR CONTENT

method	limit/base	current	history1	history2
Sulfur	ppm ASTM D5185m	<b>207</b>	---	---
Sulfur (UVF)	ppm ASTM D5453	<b>15</b>	---	---

## DISTILLATION

method	limit/base	current	history1	history2
Initial Boiling Point	°C ASTM D86	<b>171</b>	---	---
5% Distillation Point	°C ASTM D86	<b>194</b>	---	---
10% Distill Point	°C ASTM D86	<b>204</b>	---	---
15% Distillation Point	°C ASTM D86	<b>212</b>	---	---
20% Distill Point	°C ASTM D86	<b>219</b>	---	---
30% Distill Point	°C ASTM D86	<b>234</b>	---	---
40% Distill Point	°C ASTM D86	<b>247</b>	---	---
50% Distill Point	°C ASTM D86	<b>260</b>	---	---
60% Distill Point	°C ASTM D86	<b>273</b>	---	---
70% Distill Point	°C ASTM D86	<b>286</b>	---	---
80% Distill Point	°C ASTM D86	<b>300</b>	---	---
85% Distillation Point	°C ASTM D86	<b>310</b>	---	---
90% Distill Point	°C ASTM D86	<b>320</b>	---	---
95% Distillation Point	°C ASTM D86	<b>336</b>	---	---
Final Boiling Point	°C ASTM D86	<b>351</b>	---	---

## IGNITION QUALITY






method	limit/base	current	history1	history2
API Gravity	ASTM D7777	<b>35</b>	---	---
Cetane Index	ASTM D4737 <40.0	<b>45</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m <1.0	<b>&lt;1</b>	---	---
Sodium	ppm ASTM D5185m <0.1	<b>&lt;1</b>	---	---
Potassium	ppm ASTM D5185m <0.1	<b>&lt;1</b>	---	---
Water	% ASTM D6304 <0.05	<b>0.004</b>	---	---
ppm Water	ppm ASTM D6304 <500	<b>42</b>	---	---
% Gasoline	% *In-House <0.50	<b>0.0</b>	---	---
% Biodiesel	% *In-House <20.0	<b>0.0</b>	---	---



# FUEL REPORT






FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 8377	---	---
Particles >6µm	ASTM D7647	>640	▲ 1881	---	---
Particles >14µm	ASTM D7647	>80	▲ 137	---	---
Particles >21µm	ASTM D7647	>20	▲ 27	---	---
Particles >38µm	ASTM D7647	>4	1	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 20/18/14	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	---
Nickel	ppm	ASTM D5185m	<0.1	0	---
Lead	ppm	ASTM D5185m	<0.1	0	---
Vanadium	ppm	ASTM D5185m	<0.1	<1	---
Iron	ppm	ASTM D5185m	<0.1	0	---
Calcium	ppm	ASTM D5185m	<0.1	0	---
Magnesium	ppm	ASTM D5185m	<0.1	<1	---
Phosphorus	ppm	ASTM D5185m	<0.1	0	---
Zinc	ppm	ASTM D5185m	<0.1	0	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KT0001568  
**Lab Number** : 06207348  
**Unique Number** : 11074809  
**Test Package** : DF-2 ( Additional Tests: Fuel, Screen )  
**Received** : 11 Jun 2024  
**Tested** : 21 Jun 2024  
**Diagnosed** : 21 Jun 2024 - Doug Bogart

**COMPTON POWER EQUIPMENT**  
 5375 URBANA RD  
 SPRINGFIELD, OH  
 US 45502

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: Service Manager  
SALES@COMPTONEQUIPMENT.COM

T:  
F: