

# **OIL ANALYSIS REPORT**

Sample Rating Trend



# Recovery

# Bornemann FHG25AP01 Decanter Sludge Outlet Flow Pump

JAX Flow-Guard Synthetic 100 (4 QTS)

## **DIAGNOSIS**

#### Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


#### **Fluid Condition**


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		ul2019 Ma	y2020 Dec2020 Feb2	021 0ct2021 May2022 A	lug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0933667	WC0883684	WC0827149
Sample Date		Client Info		11 Jun 2024	24 Jan 2024	11 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	6	14	61
Chromium	ppm	ASTM D5185m	>15	<1	<1	<1
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		<1	<1	<1
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	2	2	<1
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m		0	0	1
Tin	ppm	ASTM D5185m	>25	<1	0	0
Vanadium	ppm	ASTM D5185m	720	0	0	<1
Cadmium	ppm	ASTM D5185m		0	0	0
	ррпп		lineit/lenene			
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	<1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	1
Magnesium	ppm	ASTM D5185m		<1	<1	7
Calcium	ppm	ASTM D5185m		0	5	2
Phosphorus	ppm	ASTM D5185m		124	120	107
Zinc	ppm	ASTM D5185m		0	0	19
Sulfur	ppm	ASTM D5185m		1782	1763	1811
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	3	8	2
Sodium	ppm	ASTM D5185m		0	0	1
Potassium	ppm	ASTM D5185m	>20	1	1	<1
Water	%	ASTM D6304	>0.2	0.006	0.002	0.008
ppm Water	ppm	ASTM D6304	>2000	66	25	80.8
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	<u>82944</u>	<u>▲</u> 141366	<u>▲</u> 142316
Particles >6µm		ASTM D7647	>5000	<u> </u>	<u></u> 53950	<u>▲</u> 27731
Particles >14µm		ASTM D7647	>640	48	637	441
Particles >21µm		ASTM D7647	>160	4	118	67
Particles >38μm		ASTM D7647	>40	1	5	2
Particles >71µm		ASTM D7647	>10	1	0	1
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<u>4</u> 24/22/13	<b>2</b> 4/23/16	<b>2</b> 4/22/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.41	0.33	0.38





## OIL ANALYSIS REPORT














**Bottom** 

Color



**GRAPHS** Ferrous Alloys Particle Count 10000 491.52 122,88 6000 4000 30.72 2000 20 8 1,920 1999 Cle Non-ferrous Metals 480 200 120 150 50 Viscosity @ 40°C Acid Number 130 (mg KOH/g) 0.60 120 0.40





Lab Number

Laboratory Sample No.

Unique Number: 11075227

: WC0933667 : 06207766

80

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

Feb 10/21

Tested Diagnosed

0ct26/21

May3/22

: 12 Jun 2024 : 18 Jun 2024 : 18 Jun 2024 - Angela Borella

Aug11/23

00.00 PG

**NOVOZYMES** P.O. BOX 576, 77 PERRY CHAPEL CHURCH ROAD FRANKLINTON, NC US 27525

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: NOVFRANC [WUSCAR] 06207766 (Generated: 06/19/2024 13:46:18) Rev: 1

Submitted By: JOSH DARNELL

Contact: BRUCE THOMAS

brct@novozymes.com

T: (919)494-3146

F: (919)494-3456