


OIL ANALYSIS REPORT



Air Compressor

{not provided} (--- GAL)





DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0037883	RP0038144	RP0030401
Sample Date		Client Info		11 Jun 2024	28 Feb 2024	10 Dec 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		14	15	12
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>4	<1	<1	0
Nickel	ppm	ASTM D5185m	>4	0	<1	0
Titanium	ppm	ASTM D5185m		<1	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>40	0	0	0
Tin	ppm	ASTM D5185m	>5	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		<1	<1	0
Calcium	ppm	ASTM D5185m		0	0	<1
Phosphorus	ppm	ASTM D5185m		0	4	71
Zinc	ppm	ASTM D5185m		0	0	0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.6	0.001	0.001	0.003
ppm Water	ppm	ASTM D6304	>6000	15	13	30
FLUID CLEANLIN	IESS _	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	594	4488	886
Particles >6µm		ASTM D7647	>2500	229	1270	129
Particles >14µm		ASTM D7647	>320	47	66	15
Particles >21µm		ASTM D7647	>80	21	14	5
Particles >38µm		ASTM D7647	>20	3	1	0
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	16/15/13	19/17/13	17/14/11
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.08	0.12	0.14



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

Lab Number

: RP0037883 : 06207776 Unique Number : 11075237

Received **Tested** Diagnosed : 12 Jun 2024

: 13 Jun 2024

: 14 Jun 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: PQ, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Kimberly-Clark - Mobile - UTL

200 BAYBRIDGE RD MOBILE, AL

US 36610 Contact: RALPH EVANS ralph.h.evans@kcc.com

T: (251)330-2250 F: (251)452-6335

Report Id: KIMMOBUTL [WUSCAR] 06207776 (Generated: 06/15/2024 10:08:51) Rev: 1

Contact/Location: RALPH EVANS - KIMMOBUTL