

OIL ANALYSIS REPORT



Machine Id

4301766 (S/N 1178)

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017997	KCPA002925	
Sample Date		Client Info		30 May 2024	29 Aug 2023	
Machine Age	hrs	Client Info		97115	94468	
Dil Age	hrs	Client Info		2000	0	
Dil Changed		Client Info		Not Changd	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
ron	ppm	ASTM D5185m	>50	<1	1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	3	
Fitanium	ppm	ASTM D5185m		<1	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	2	
ead		ASTM D5185m	>10	2 <1	0	
	ppm					
Copper	ppm		>50	1	11	
Fin /	ppm	ASTM D5185m	>10	<1	0	
/anadium	ppm	ASTM D5185m		0	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	54	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	54	2	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		3	<1	
Zinc	ppm	ASTM D5185m		4	5	
Sulfur	ppm	ASTM D5185m		19456	21429	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		11	1	
Potassium	ppm	ASTM D5185m	>20	4	2	
Vater	%	ASTM D6304	>0.05	0.023	▲ 0.272	
opm Water	ppm	ASTM D6304	>500	235	▲ 2720	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		10755	8582	
Particles >6µm		ASTM D7647	>1300	A 3121	2867	
Particles >14µm		ASTM D7647	>80	A 226	1 56	
Particles >21µm		ASTM D7647	>20	<u> </u>	<u> </u>	
Particles >38µm		ASTM D7647		2	1	
Particles >71µm		ASTM D7647		0	1	
Dil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	. 20/19/14	
	TION	method	limit/base	current		history2
						historyz
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.39	0.35	
FLUID DEGRADA		method ASTM D8045	limit/base	current 0.39	history1 0.35	

Contact/Location: C. SCHELIGA - MEDPOMCA Page 1 of 2



Built for a lifetime."

OIL ANALYSIS REPORT

2k T	VISUAL		method	limit/base	current	history1	history2
0k	White Metal	scalar	*Visual	NONE	NONE	MODER	
8k - 14µm	Yellow Metal	scalar	*Visual	NONE	NONE	NONE	
6k -	Precipitate	scalar	*Visual	NONE	NONE	NONE	
4k	Silt	scalar	*Visual	NONE	NONE	NONE	
	Debris	scalar	*Visual	NONE	NONE	NONE	
2k	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	
0k 127	Appearance	scalar	*Visual	NORML	NORML	NORML	
Aug29/23 May30/24	Odor	scalar	*Visual	NORML	NORML	NORML	
	Emulsified Water	scalar	*Visual	>0.05	-	▲ 0.2%	
Water (KF)	Free Water	scalar	*Visual	20.00	NEG	NEG	
00 - Severe	FLUID PROPERT			limit/bases			biotom/0
100 -				limit/base	current	history1	history2
00-	Visc @ 40°C	cSt	ASTM D445	46	45.2	44.6	
000	SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Abnomal C CZ 6260 V W 9/2005/e W	Color						no image
Acid Number	Bottom						no image
.30	GRAPHS	_					
20-	Ferrous Alloys				Particle Count		
10 -	¹⁰			491,52			T ²⁶
00	8 - iron chromium			122,88			+24
Aug29/23	E 6-			122,00			12.1
Aug'	4			30,72	D-		-22
Water (KF)	2	Sale Charles Continues	Territoria de la constante de la c	7,68			20
	2 2						+20 +18 +18 +16 +14
Severe	Aug29/23			May30/24 s (per 1 ml			-18
100 -	⊲ Non-ferrous Meta			May30/24 - particles (per 1 ml) 86		N	10
00 -	15 _T						10
100 -	copper			of 12	0-		-14
100 -	10- E			3	n		-12
Abnormal	5-						
1/23			A REAL PROPERTY AND A REAL		⁸ Béværnal		10
Aug29/23	0 S			24	2		
-	Aug29/23			May30/2			
Viscosity @ 40°C				Ň	0 4μ 6μ	14µ 21µ	38µ 71µ
Abnormal 50 -	Viscosity @ 40°C				Acid Number		
48 -	Abnormal			(^{0.5} Hoy 0.4	Base		· · · · · · · · · · · · · · · · · · ·
46 - Base	50+			9 U.4			
44	± 45 -			50.3 50.2			
42	40 - Abnormal			V.0.1	0		
40 - Abnormal	35				0		
38 	Aug29/23			May30/24	Aug29/23		Mav30/24
Aug29/23	Aug			May	Aug		Mav
Laboratory Sample No. Lab Number Unique Number Test Package		Recei Teste Diagn sts: KF, P	ved : 12 d : 13 osed : 14 rtCount)	2 Jun 2024 3 Jun 2024 Jun 2024 - Dor		2727 THOMPSC	POMONA, CA US 91767 C. SCHELIGA

Contact/Location: C. SCHELIGA - MEDPOMCA