


OIL ANALYSIS REPORT

Sample Rating Trend







Machine Id

4400253 (S/N 1069)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan 2024	May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA012954	KCPA006546	
Sample Date		Client Info		28 May 2024	16 Jan 2024	
Machine Age	hrs	Client Info		0	29412	
Oil Age	hrs	Client Info		0	0	
Oil Changed	1113	Client Info		Changed	N/A	
Sample Status		Olletti IIIIO		NORMAL	NORMAL	
				NOTIMAL	NOTTIVIAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	2	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	15	38	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	90	0	0	
Calcium	ppm	ASTM D5185m	2	0	0	
Phosphorus	ppm	ASTM D5185m		4	0	
Zinc	ppm	ASTM D5185m		<1	0	
Sulfur	ppm	ASTM D5185m		11094	15034	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		0	0	
Potassium	ppm	ASTM D5185m	>20	<1	<1	
Water	%	ASTM D6304	>0.05	0.006	0.009	
ppm Water	ppm	ASTM D6304	>500	65	97	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		645		
Particles >6µm		ASTM D7647	>1300	145		
Particles >14µm		ASTM D7647	>80	24		
Particles >21µm		ASTM D7647	>20	10		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/14/12		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.45	0.40	



OIL ANALYSIS REPORT







Laboratory Sample No.

Lab Number Unique Number : 11075281

: KCPA012954 : 06207820

Received : 12 Jun 2024 **Tested** Diagnosed

: 13 Jun 2024 : 14 Jun 2024 - Don Baldridge

13429 ALONDRA BLVD SANTA FE SPRINGS, CA US 90670 Contact: Service Manager

Test Package : IND 2 (Additional Tests: KF, PrtCount) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - HERSANCAL

T:

F: