

## **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SK 15 4026809 (S/N 1027)

Component Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017936	KCPA006876	KCP53591
Sample Date		Client Info		30 May 2024	07 Nov 2023	06 Apr 2023
Machine Age	hrs	Client Info		33428	30674	27395
Oil Age	hrs	Client Info		3000	0	3000
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	1	1	<1
Tin	ppm	ASTM D5185m	>10	<1	0	0
Vanadium	ppm	ASTM D5185m		0	<1	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	74	72	55
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	100	86	90	93
Calcium	ppm	ASTM D5185m	0	0	<1	0
Phosphorus	ppm	ASTM D5185m	0	0	0	0
Zinc	ppm	ASTM D5185m	0	0	1	0
Sulfur	ppm	ASTM D5185m	23500	21131	20555	22891
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		16	7	14
Potassium	ppm	ASTM D5185m	>20	11	<1	0
Water	%	ASTM D6304	>0.05	0.020	0.011	0.012
ppm Water	ppm	ASTM D6304	>500	205	117.6	129.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2944	17931	857
Particles >6µm		ASTM D7647	>1300	1006	<b>4</b> 304	209
Particles >14µm		ASTM D7647	>80	75	<b>1</b> 99	13
Particles >21µm		ASTM D7647	>20	17	<mark>▲</mark> 37	4
Particles >38µm		ASTM D7647	>4	1	1	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	17/13	<b>1</b> 9/15	15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.36	0.33	0.37


Contact/Location: JOHN FIECHTNER - STILON Page 1 of 2




**OIL ANALYSIS REPORT** 










Δ

Certif

VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	46.4	45.7	46.3
SAMPLE IMAGES meth		method	limit/base	current	history1	history2
Color						



Bottom





<b>TAB</b>	Sample N
REDITED	Lab Numb
IG LABORATORY	Unique Num
	Tost Packa

ber : 11075293

Diagnosed

: 14 Jun 2024 - Angela Borella Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: STILON [WUSCAR] 06207832 (Generated: 06/15/2024 10:49:24) Rev: 1

Contact/Location: JOHN FIECHTNER - STILON Page 2 of 2

Contact: JOHN FIECHTNER

Т:

F:

john.fiechtner@stickergiant.com