


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER 8074432 (S/N 1140)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### **DIAGNOSIS**

### Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jul2022	Jun2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
	77 (1101)		IIIIII Daoc			
Sample Number		Client Info		KCPA012267	KCP51649	
Sample Date		Client Info		05 Jun 2024	29 Jul 2022	
Machine Age	hrs	Client Info		1849	751	
Oil Age	hrs	Client Info		1848	751	
Oil Changed		Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	<1	<1	
Copper	ppm	ASTM D5185m	>50	2	2	
Tin	ppm	ASTM D5185m	>10	<1	<1	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	100	<b>66</b>	<u>^</u> 72	
Calcium	ppm	ASTM D5185m	0	0	<1	
Phosphorus	ppm	ASTM D5185m	0	0	2	
Zinc	ppm	ASTM D5185m	0	10	13	
Sulfur	ppm	ASTM D5185m	23500	20632	18593	
CONTAMINANTS	i	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	
Sodium	ppm	ASTM D5185m		12	12	
Potassium	ppm	ASTM D5185m	>20	3	0	
Water	%	ASTM D6304	>0.05	<b>0.064</b>	0.027	
ppm Water	ppm	ASTM D6304	>500	<b>△</b> 648	278.4	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		4776	5600	
Particles >6µm		ASTM D7647	>1300	<u>2221</u>	<u>^</u> 2129	
Particles >14µm		ASTM D7647	>80	<u> </u>	<u> </u>	
Particles >21µm		ASTM D7647	>20	<b>9</b> 31	<b>▲</b> 37	
Particles >38µm		ASTM D7647	>4	2	2	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>19/18/15</b>	<u>^</u> 20/18/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
A sial Niversland (ANI)		AOTA DOO45	1.0	0.27	0.24	

Acid Number (AN)


mg KOH/g ASTM D8045 1.0

0.34

0.37



# OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

Lab Number

: KCPA012267 : 06207841

Unique Number : 11075302

Received **Tested** Diagnosed

: 12 Jun 2024 : 13 Jun 2024

: 14 Jun 2024 - Angela Borella

76 BUSINESS PARKWAY RD LINN CREEK, MO US 65052

Contact: Service Manager

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - LAKLIN

T:

F: