




# OIL ANALYSIS REPORT

Sample Rating Trend



**NORMAL**



Machine Id  
**C-8 (S/N F0249YFMCTHAA03)**  
 Component  
**Refrigeration Compressor**  
 Fluid  
**USPI ALT-68 SC (--- GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>USP0013412</b>	USP0003524	USP0000603
Sample Date	Client Info	<b>11 Jun 2024</b>	23 Nov 2023	16 Aug 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	<b>N/A</b>	N/A	N/A
Sample Status		<b>NORMAL</b>	NORMAL	NORMAL

## WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >8	0	0
Chromium	ppm	ASTM D5185m >2	0	<1
Nickel	ppm	ASTM D5185m	0	<1
Titanium	ppm	ASTM D5185m	0	<1
Silver	ppm	ASTM D5185m >2	0	0
Aluminum	ppm	ASTM D5185m >3	0	1
Lead	ppm	ASTM D5185m >2	0	0
Copper	ppm	ASTM D5185m >8	0	<1
Tin	ppm	ASTM D5185m >4	0	0
Vanadium	ppm	ASTM D5185m	<1	0
Cadmium	ppm	ASTM D5185m	0	<1

## ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0
Barium	ppm	ASTM D5185m	0	0
Molybdenum	ppm	ASTM D5185m	0	<1
Manganese	ppm	ASTM D5185m	0	0
Magnesium	ppm	ASTM D5185m	<1	0
Calcium	ppm	ASTM D5185m	0	<1
Phosphorus	ppm	ASTM D5185m	<1	0
Zinc	ppm	ASTM D5185m	0	0
Sulfur	ppm	ASTM D5185m 50	0	0

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	<1	<1
Sodium	ppm	ASTM D5185m	0	0
Potassium	ppm	ASTM D5185m >20	<1	1
Water	%	ASTM D6304 >0.01	<b>0.005</b>	0.003
ppm Water	ppm	ASTM D6304 >100	<b>56</b>	34

## FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	<b>427</b>	554	408
Particles >6µm	ASTM D7647 >2500	<b>109</b>	143	137
Particles >14µm	ASTM D7647 >320	<b>7</b>	18	19
Particles >21µm	ASTM D7647 >80	<b>1</b>	9	6
Particles >38µm	ASTM D7647 >20	<b>0</b>	5	1
Particles >71µm	ASTM D7647 >4	<b>0</b>	2	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	<b>16/14/10</b>	16/14/11	16/14/11

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974 0.005	<b>0.014</b>	0.014



# OIL ANALYSIS REPORT




VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.01	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	65.6	67.3	67.4






SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color



Bottom

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : USP0013412  
 Lab Number : 06207907  
 Unique Number : 11075368  
 Test Package : IND 2

Received : 12 Jun 2024  
 Tested : 14 Jun 2024  
 Diagnosed : 15 Jun 2024 - Doug Bogart

CONAGRA - LOUISVILLE  
 12730H WESTPORT RD  
 LOUISVILLE, KY  
 US 40245  
 Contact: SCOTT CASTILLO

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: