

## **OIL ANALYSIS REPORT**

## Area PG-46 [SO-284356] Machine Id PNEUTECH AK100017024 - CARLSON AIRFLOW MERCH SYSTEMS Component

Component Compressor

## DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

## Wear


All component wear rates are normal.

## Contamination

There is no indication of any contamination in the oil.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



Sample Rating Trend




NORMAL

SAMPLE INFORM	<b>MATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0002346		
Sample Date		Client Info		07 Jun 2024		
Machine Age	hrs	Client Info		6342		
Oil Age	hrs	Client Info		2939		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		207		
Zinc	ppm	ASTM D5185m		24		
Sulfur	ppm	ASTM D5185m		333		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.087		



# **OIL ANALYSIS REPORT**



	VISUAL		method	limit/base	current	history1	history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Jun7/24	Appearance	scalar	*Visual	NORML	NORML			
٦ ۲	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPERT	<b>FIES</b>	method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		44.9			
	SAMPLE IMAGES	S	method	limit/base	current	history1	history2	
- + <del>1</del> 2/7mJ	Color				•	no image	no image	
	Bottom					no image	no image	
	Non-ferrous Metal	ls		92/LmJ/24				
	Viscosity @ 40°C			+2/Lunf	Acid Number			
	50 - Abnormal			KOH	-			
	(2) 0) 0) 0) 0) 0 0 0 0 0 0 0 0 0 0 0 0 0			0.10 80.00 90.00 90.00 90.0 Voi 90.0 Vo				
	Jun7/24			+5/LnuL	Jun7/24			
Laboratory Sample No. Lab Number Unique Number		1 Madiso Rece Teste Diagr	ived : 12 ed : 14	, NC 27513 2 Jun 2024 4 Jun 2024 9 Jun 2024 - W		FLUID-AIRE DYNAMICS - (M 14250 JUDICIAL ROA BURNSVILLE, M US 5530 Contact: Service Manag		

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - UCFLUBUR

F: