

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area **PG-46** [290571] Machine Id **PNEUTECH AK100021208** Component

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0002335		
Sample Date		Client Info		06 Jun 2024		
Machine Age	hrs	Client Info		3598		
Oil Age	hrs	Client Info		3598		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		387		
Zinc	ppm	ASTM D5185m		3		
Sulfur	ppm	ASTM D5185m		108		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.41		



OIL ANALYSIS REPORT



Laboratory Sample No. Lab Number Unique Number	: UFD0002335 : <mark>06207926</mark>	Recei Teste	Madison Ave., Cary, NC 27513 Received : 12 Jun 2024 Tested : 14 Jun 2024 Diagnosed : 14 Jun 2024 - Wes Davis the at 1-800-237-1369. 025 scope of accreditation.			FLUID-AIRE DYNAMICS - (MN) 14250 JUDICIAL ROAD BURNSVILLE, MN US 55306 Contact: Service Manager T:		
	Viscosity @ 40°C				20	r	Jun6/24	
	Ferrous Alloys	ls		Jun6/24				
	Bottom					no image	no image	
Jun6/24	SAMPLE IMAGE	S	method	limit/base	current	history1	history2 no image	
	Visc @ 40°C	cSt	ASTM D445		50.2			
	Free Water	scalar	*Visual method	limit/base	NEG current	 history1	 history2	
ר ר	Odor Emulsified Water	scalar scalar	*Visual *Visual	NORML >0.1	NORML NEG			
Jun6/24	Sand/Dirt Appearance	scalar scalar	*Visual *Visual	NONE NORML	NONE NORML			
	Silt Debris	scalar scalar	*Visual *Visual	NONE	NONE			
	Yellow Metal Precipitate	scalar	*Visual *Visual	NONE	NONE			
	White Metal	scalar	*Visual	NONE	NONE			

Contact/Location: Service Manager - UCFLUBUR