


OIL ANALYSIS REPORT

PG46 [279178] PNEUTECH API861863 - OERLIKON

Component Compressor



DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The oil viscosity is higher than normal. The AN level is above the recommended limit.


SAMPLE INFORM						
O/ WIT ELE II VI OT III	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000527		
Sample Date		Client Info		10 May 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		12		
Zinc	ppm	ASTM D5185m		<1		
Sulfur	ppm	ASTM D5185m		30		
	}	method	limit/base	current	history1	history2
CONTAMINANTS						
CONTAMINANTS Silicon	ppm	ASTM D5185m	>25	9		
Silicon	ppm ppm	ASTM D5185m ASTM D5185m	>25	9 2		
Silicon Sodium		ASTM D5185m	>25 >20			
	ppm ppm	ASTM D5185m		2		




OIL ANALYSIS REPORT


















Certificate 12367

Laboratory Sample No.

Lab Number : 06208763

: UFD0000527 Unique Number : 11076224

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 13 Jun 2024 **Tested** : 14 Jun 2024

Diagnosed : 14 Jun 2024 - Angela Borella

Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Contact: ED DIENER ed.diener@fluidairedynamics.com

FLUID-AIRE DYNAMICS

225 SPRING LAKE DR

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (847)678-8388

ITASCA, IL

US 60143