

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area LSS-9300-5 Machine Id SULLAIR 003-77507 - MERIDIAN

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06208857		
Sample Date		Client Info		19 Mar 2024		
Machine Age	hrs	Client Info		389		
Oil Age	hrs	Client Info		380		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		259		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		461		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		1.28		



OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
· · · · · · · · · · · · · · · · · · ·	Silt	scalar	*Visual	NONE	NONE			
1	Debris	scalar	*Visual	NONE	NONE			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Marl 9/24	Appearance	scalar	*Visual	NORML	NORML			
M	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.1	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPER		method	limit/base	current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445		42.4			
	SAMPLE IMAGE	S	method	limit/base	current	history1	history2	
Mar19/24	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Meta	ls		Mar19/24				
	Viscosity @ 40°C			Mar19/24 Mar19/24	Acid Number			
Laboratory Sample No. Lab Number Unique Number	: WearCheck USA - 50 : UCH06208857 : 06208857	Recei Teste	ladison Ave., Cary, NC 27513 LEWIS Received : 13 Jun 2024 Tested : 14 Jun 2024 Diagnosed : 14 Jun 2024 - Wes Davis at 1-800-237-1369.			SYSTEMS & SERVICE CO IN 9300 STOCKPORT P CHARLOTTE, N US 2827 Contact: SCOTT KE skee@lewissystemsinc.cor		

Report Id: UCLEWCHA [WUSCAR] 06208857 (Generated: 06/14/2024 15:37:07) Rev: 1

Contact/Location: SCOTT KEE - UCLEWCHA