


# **FUEL REPORT**

[PMOAS3263459] 13994550700 - GEN 4 (S/N 2114769)

**Diesel Fuel** 

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- QTS)





## DIAGNOSIS

### Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

## Corrosion

All metal levels are normal indicating no corrosion in the system.

### **Contaminants**

The water content is negligible. There is no Bacteria, Yeast and/or Fungus indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.


## **Fuel Condition**

Sulfur value derived by ASTM D4294 method for ULSD validation. Sulfur level is acceptable for ULSD specification.


H) ( Q15)		Ma	y2022	Aug2023 Jun20	24	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number Sample Date Machine Age Sample Status	hrs	Client Info Client Info Client Info		DC0036953 06 Jun 2024 749 NORMAL	DC0030149 24 Aug 2023 712 NORMAL	DC0014137 04 May 2022 618 NORMAL
PHYSICAL PROP	PERTIES	method	limit/base	current	history1	history2
ASTM Color Visc @ 40°C	scalar cSt	*ASTM D1500 ASTM D445	3.0	L4.0 2.53	L4.0 2.46	L5.5 2.53
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur Sulfur (UVF)	ppm ppm	ASTM D5185m ASTM D5453	10	0 8	0	2 11
IGNITION QUALIT	ГΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	37.3	37.3	37.0
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon Sodium	ppm ppm	ASTM D5185m ASTM D5185m	<1.0 <0.1	<1 2	0	<1 0
Potassium	ppm	ASTM D5185m	<0.1	2	0	0
Water ppm Water % Gasoline	% ppm %	ASTM D6304 ASTM D6304 *In-House	<500 <0.50	0.003 28 0.0	0.003 30.6 0.0	0.002 18.9 0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0	0.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm Particles >6µm Particles >14µm Particles >21µm Particles >38µm Particles >71µm Oil Cleanliness		ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ASTM D7647 ISO 4406 (c)	>80 >20 >4 >3	395 142 27 9 1 0 16/14/12		15327 3466 319 94 3 0 21/19/15
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum Nickel Lead	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	<0.1 <0.1 <0.1	0 <1 0	0 0 0	0 <1 0
Vanadium Iron Calcium	ppm ppm	ASTM D5185m ASTM D5185m	<0.1 <0.1 <0.1	0 0 0	0 0 0	0 0 <1
Magnesium Phosphorus	ppm ppm	ASTM D5185m ASTM D5185m ASTM D5185m	<0.1 <0.1 <0.1	<1 0	<1 0	0 <1
Zinc	ppm	ASTM D5185m	<0.1	<1	0	0



# **FUEL REPORT**











Certificate 12367

Laboratory

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 **Sample No.** : DC0036953 Lab Number : 06209103 Unique Number : 11076564

Received **Tested** Diagnosed

: 13 Jun 2024 : 20 Jun 2024 : 20 Jun 2024 - Elizabeth Valachovic

**KELLY GENERATOR & EQUIPMENT INC** Test Package: DF-5 (Additional Tests: API, Cetane, Fuel, PrtCount, Screen)

OWINGS, MD US 20736 Contact: LESLIE SNURR LSNURR@KGE.COM

1955 DALE LN

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

T: (410)257-5225 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (410)257-5227

Report Id: KELOWI [WUSCAR] 06209103 (Generated: 06/22/2024 06:15:22) Rev: 1