

OIL ANALYSIS REPORT

Sample Rating Trend

ADDITIVES

Machine Id KAESER DSD175 7765571 (S/N 1150)

Component Compressor

Fluid KAESER SIGMA (OEM) FG-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

Additive levels indicate the addition of a different brand, or type of oil. Confirm oil type.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA017601	KCP40228D	KCP34826
Sample Date		Client Info		10 Jun 2024	01 Nov 2022	10 Feb 2022
Machine Age	hrs	Client Info		13237	5807	2466
Oil Age	hrs	Client Info		6186	3341	2466
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	3	0	<1
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	1	2	<1
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m		1	5	9
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		۰ <1	0	0
	ppill					
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		4	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		1	0	11
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	<mark> </mark> 23	43	2
Zinc	ppm	ASTM D5185m		<mark> </mark> 3	23	0
Sulfur	ppm	ASTM D5185m		<mark> </mark> 134	2495	15648
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	<1
Sodium	ppm	ASTM D5185m		<1	0	3
Potassium	ppm	ASTM D5185m	>20	<1	0	0
Water	%	ASTM D6304	>0.05	0.003	0.003	0.010
ppm Water	ppm	ASTM D6304	>500	27	38.0	100.9
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		7814	1447	2945
Particles >6µm		ASTM D7647	>1300	<u> </u>	202	998
Particles >14µm		ASTM D7647	>80	<u> </u>	13	89
Particles >21µm		ASTM D7647	>20	23	5	16
Particles >38µm		ASTM D7647	>4	1	0	1
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>	18/15/11	17/14
FLUID DEGRADA		method	limit/base	current	history1	history2
FLUID DEGRADA		methou	IIIIII/Dase	Current	HISLOIV	11310172

Report Id: PILLIVFL [WUSCAR] 06209241 (Generated: 06/17/2024 15:26:27) Rev: 1

Contact/Location: KARLA BOLIN - PILLIVFL



Water

0.00

1200

1000

4000

2000

r (ppm)

Water

-qa

Water (KF)

Abnorma

OIL ANALYSIS REPORT

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

cSt

method

*Visual

*Visual

*Visual

*Visual

*Visual

*Visual

*Visual

*Visual

method

ASTM D445

method

scalar *Visual

scalar *Visual

limit/base

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

limit/base

>0.05

46

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML


curren


Particle Count

NEG

NEG

49.0





history1

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

history

NEG

NEG

47.0

history2

NONE

NONE

NONE

NONE

NONE

NONE

NORML


NORML

history2

NEG

NEG

45.2



Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate 12367

Contact/Location: KARLA BOLIN - PILLIVFL