

OIL ANALYSIS REPORT

Sample Rating Trend



Area FGG 1150 Machine Id SC 4 - BUFFALO WATER Gearbox

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06210086		
Sample Date		Client Info		13 Jun 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	<1		
Chromium	ppm	ASTM D5185m	>15	0		
Nickel	ppm	ASTM D5185m	>15	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>100	0		
Copper	ppm	ASTM D5185m	>200	0		
Tin	ppm	ASTM D5185m	>25	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	0	0		
Molybdenum	ppm	ASTM D5185m	0.1	0		
Manganese	ppm	ASTM D5185m	0.2	0		
Magnesium	ppm	ASTM D5185m	1.8	0		
Calcium	ppm	ASTM D5185m	0	<1		
Phosphorus	ppm	ASTM D5185m	573	479		
Zinc	ppm	ASTM D5185m	0	15		
Sulfur	ppm	ASTM D5185m	576	789		
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	3		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.425	0.13		



Jun1

OIL ANALYSIS REPORT



	VISUAL		method	limit/bas	e current	history1	history2	
	White Metal	scalar	*Visual	NONE	NONE			
	Yellow Metal	scalar	*Visual	NONE	NONE			
	Precipitate	scalar	*Visual	NONE	NONE			
	Silt	scalar	*Visual	NONE	NONE			
	Debris	scalar	*Visual	NONE	A MODER			
	Sand/Dirt	scalar	*Visual	NONE	NONE			
Jun 13/24	Appearance	scalar	*Visual	NORML	NORML			
ημη	Odor	scalar	*Visual	NORML	NORML			
	Emulsified Water	scalar	*Visual	>0.2	NEG			
	Free Water	scalar	*Visual		NEG			
	FLUID PROPER	TIES	method	limit/bas	e current	history1	history2	
	Visc @ 40°C	cSt	ASTM D445	152.9	138			
	SAMPLE IMAGE	S	method	limit/bas	e current	history1	history2	
	Color					no image	no image	
	Bottom					no image	no image	
	Non-ferrous Meta	ls		Jun13/24				
	Viscosity @ 40°C			Jun13/24	Acid Number			
	160 Base 150 3140 130 Abnormal 20 *2			Acid Numbe	0.50 0.40 0.30 0.20 0.10 0.00			
Laboratory Sample No. Lab Number Unique Number Test Package		Rece Teste Diagr sts: PrtCo	ived : 14 ed : 18 nosed : 18 punt)	l Jun 2024 3 Jun 2024 Jun 2024 - A		DSION PRODUCTS & EQUIPMENT IN 110 ELMGROVE PAR ROCHESTER, N US 1462 Contact: Bill Co cox@corrosion-products.com		

Report Id: UCCORROC [WUSCAR] 06210086 (Generated: 06/22/2024 19:11:18) Rev: 1

Contact/Location: Bill Cox - UCCORROC

Page 2 of 2