




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
KAESER ACSM 15 3918442 (S/N 1270)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KCPA018276	KCP53223	KCP28457
Sample Date	Client Info			04 Jun 2024	11 Apr 2023	15 Mar 2021
Machine Age	hrs	Client Info		25243	21788	13716
Oil Age	hrs	Client Info		3455	0	612
Oil Changed	Client Info			Changed	Changed	Not Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	2
Aluminum	ppm	ASTM D5185m	>10	1	<1	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	7	14	2
Tin	ppm	ASTM D5185m	>10	<1	0	0
Antimony	ppm	ASTM D5185m		---	---	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	0	2
Barium	ppm	ASTM D5185m	90	0	0	11
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	100	18	13	62
Calcium	ppm	ASTM D5185m	0	0	1	<1
Phosphorus	ppm	ASTM D5185m	0	0	3	2
Zinc	ppm	ASTM D5185m	0	0	29	10
Sulfur	ppm	ASTM D5185m	23500	21110	24205	17738

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	21	▲ 36	5
Sodium	ppm	ASTM D5185m		9	2	16
Potassium	ppm	ASTM D5185m	>20	5	0	5
Water	%	ASTM D6304	>0.05	0.015	0.010	0.022
ppm Water	ppm	ASTM D6304	>500	156	109.3	223.8

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		451	1428	3626
Particles >6µm		ASTM D7647	>1300	153	587	1264
Particles >14µm		ASTM D7647	>80	11	● 100	▲ 249
Particles >21µm		ASTM D7647	>20	1	15	▲ 81
Particles >38µm		ASTM D7647	>4	0	0	4
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>17/13	14/11	● 16/14	▲ 17/15

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.37	0.43	0.309


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	49.8	53.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA018276 **Received** : 14 Jun 2024
Lab Number : 06210153 **Tested** : 18 Jun 2024
Unique Number : 11083017 **Diagnosed** : 18 Jun 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

BRAINTREE PRINTING
 230 WOOD RD
 BRAINTREE, MA
 US 02184
 Contact: J. TAFUR
 jtafur@braintreeprinting.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)