


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

7317999 (S/N 1107)Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2021	Apr2022	Sep2022 Nov2023	May2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018807	KCPA009427	KCP50085
Sample Date		Client Info		31 May 2024	07 Nov 2023	22 Sep 2022
Machine Age	hrs	Client Info		19716	16653	10378
Oil Age	hrs	Client Info		3063	0	5372
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				NORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	6	8	11
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	0	0	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	0	3
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	23500	18877	11872	16351
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	1
Sodium	ppm	ASTM D5185m	720	1	<1	0
Potassium	ppm		>20	3	0	0
Water	%	ASTM D6304	>0.05	0.005	0.003	0.002
ppm Water	ppm	ASTM D6304	>500	56	27.5	20.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1048	5358	1641
Particles >6µm		ASTM D7647	>1300	239	1944	237
Particles >14µm		ASTM D7647	>80	33	▲ 197	21
Particles >21µm		ASTM D7647		12	<u></u> 58	9
Particles >38µm		ASTM D7647	>4	1	3	1
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/12	△ 20/18/15	18/15/12
FLUID DEGRADA	TION_	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.45	0.42	0.46



OIL ANALYSIS REPORT







Certificate 12367

Laboratory

Sample No. Lab Number

: 06210157 Unique Number : 11083021

: KCPA018807

Received : 14 Jun 2024 **Tested** : 18 Jun 2024 Diagnosed : 18 Jun 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - 84LLAV

136 WHEELER ST

Contact: Service Manager

LAVERGNE, TN

US 37686

T:

F: