

OIL ANALYSIS REPORT

Sample Rating Trend

VIS DEBRIS

Machine Id

KAESER ASD 40ST 5869630 (S/N 3740) Component Compressor

Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

All component wear rates are normal.

Contamination

High concentration of visible dirt/debris present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


SAMPLE INFORM	/IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCP60887	KCPA005086	KCP52775
Sample Date		Client Info		06 Jun 2024	26 Jun 2023	19 Dec 2022
Machine Age	hrs	Client Info		16772	14713	14621
Oil Age	hrs	Client Info		932	0	5459
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	1	1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		3	2	6
Tin	ppm		>10	<1	0	0
Vanadium	ppm	ASTM D5185m	-	0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	<1	0	0
Barium	ppm	ASTM D5185m	90	<1	18	5
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	52	74	25
Calcium	ppm	ASTM D5185m	0	0	2	<1
Phosphorus	ppm	ASTM D5185m	0	<1	6	4
Zinc	ppm	ASTM D5185m	0	0	3	14
Sulfur	ppm	ASTM D5185m	23500	24154	24131	21897
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	<1
Sodium	ppm	ASTM D5185m		17	8	2
Potassium	ppm	ASTM D5185m	>20	6	4	1
Water	%	ASTM D6304	>0.05	0.019	0.023	0.006
ppm Water	ppm	ASTM D6304	>500	190	230.5	69.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			5910	
Particles >6µm		ASTM D7647	>1300		1 925	
Particles >14µm		ASTM D7647	>80		1 77	
Particles >21µm		ASTM D7647	>20		4 9	
Particles >38µm		ASTM D7647	>4		2	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		▲ 20/18/15	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.42	0.41	0.52


Contact/Location: SERVICE MANAGER ? - POMSAV Page 1 of 2



OIL ANALYSIS REPORT









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	LIGHT	NONE
Debris	scalar	*Visual	NONE	🔺 HEAVY	NONE	🔺 MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	46.2	45.9	48.3
SAMPLE IMAGES		method	limit/base	current	history1	history2

Color



Bottom



: 18 Jun 2024 - Don Baldridge

Diagnosed

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Report Id: POMSAV [WUSCAR] 06210164 (Generated: 06/22/2024 03:37:19) Rev: 1

Certificate 12367

Unique Number : 11083028

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Contact/Location: SERVICE MANAGER ? - POMSAV

US 55378

T:

F:

Contact: SERVICE MANAGER