


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

5657031 (S/N 1056)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

Excessive free water present. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018930	KCPA002232	
Sample Date		Client Info		11 Jun 2024	06 Jun 2023	
Machine Age	hrs	Client Info		25875	17204	
Oil Age	hrs	Client Info		8671	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	4	5	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	<1	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	<1	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		0	0	
Magnesium	ppm	ASTM D5185m	100	<1	0	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	8	0	
Zinc	ppm	ASTM D5185m	0	6	0	
Sulfur	ppm	ASTM D5185m	23500	17210	18076	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	
Sodium	ppm	ASTM D5185m		0	1	
Potassium	ppm	ASTM D5185m	>20	1	0	
Water	%	ASTM D6304	>0.05	△ 0.056	0.008	
ppm Water	ppm	ASTM D6304	>500	△ 560	82.1	
FLUID CLEANLINE	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		339	485	
Particles >6µm		ASTM D7647	>1300	185	136	
Particles >14µm		ASTM D7647	>80	31	16	
Particles >21μm		ASTM D7647	>20	11	5	
Particles >38μm		ASTM D7647	>4	2	0	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/15/12	16/14/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma 1/011/a	ACTM DODAE	1.0	0.50	0.07	

Acid Number (AN)


mg KOH/g ASTM D8045 1.0

0.07

0.50



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

Lab Number

: 06210791 Unique Number : 11083655

: KCPA018930 Received **Tested**

: 14 Jun 2024 : 18 Jun 2024 Diagnosed

: 18 Jun 2024 - Angela Borella

5525 US 60 OWENSBORO, KY US 42301

Contact: Service Manager Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: AIROWE [WUSCAR] 06210791 (Generated: 06/19/2024 08:52:19) Rev: 1

Contact/Location: Service Manager - AIROWE

T:

F: