

OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

KAESER 8499578

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

	O.		$\overline{}$		
	G١	м	-	124	

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun 2023	Jun 2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC130221	KC101184	
Sample Date		Client Info		05 Jun 2024	01 Jun 2023	
Machine Age	hrs	Client Info		2494	915	
Oil Age	hrs	Client Info		1579	915	
Oil Changed	1115	Client Info		Changed	Changed	
Sample Status		Ciletit iiiio		NORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	0	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	4	2	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	37	41	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	77	78	
Calcium	ppm	ASTM D5185m	2	0	2	
Phosphorus	ppm	ASTM D5185m		7	<1	
Zinc	ppm	ASTM D5185m		5	3	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	1	
Sodium	ppm	ASTM D5185m	7 _ 0	17	12	
Potassium	ppm	ASTM D5185m	>20	8	10	
Water	%	ASTM D6304	>0.05	0.008	0.028	
ppm Water	ppm	ASTM D6304	>500	85	283.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3108	5388	
Particles >6µm		ASTM D7647	>1300	1105	1604	
Particles >14µm		ASTM D7647	>80	50	92	
Particles >21µm		ASTM D7647	>20	7	20	
Particles >38µm		ASTM D7647	>4	0	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	20/18/14	
	TION					
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.4

0.35

0.36



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: KC130221 Lab Number : 06210797 Unique Number : 11083661 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 14 Jun 2024 **Tested** : 20 Jun 2024 Diagnosed

: 21 Jun 2024 - Jonathan Hester

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) 5414 HWY 2 W

US 59912

T:

F:

COLUMBIA FALLS, MT

Contact: Service Manager