




# FUEL REPORT

Sample Rating Trend



ISO



Area

## STEAM CHILLER

Machine ID

## DUKE HOSPITAL 250000 GALLON TANK

Component

### Diesel Fuel

Fluid

### No.2 DIESEL FUEL (ULTRALOW SULPHUR) (250000 GAL)

#### DIAGNOSIS

##### Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

##### Corrosion

All metal levels are normal indicating no corrosion in the system.

##### Contaminants

There is a high amount of particulates present in the fuel. Light concentration of visible dirt/debris present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible.

##### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

#### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0949581</b>	WC05303119	WC04753258
Sample Date	Client Info		<b>14 Jun 2024</b>	14 Jul 2021	11 Jul 2019
Machine Age	hrs	Client Info	<b>0</b>	0	0
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

#### PHYSICAL PROPERTIES

	method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298	0.839	---	0.842	0.842
Fuel Color	text	*Visual Screen	<b>Red</b>	Red	Red
ASTM Color	scalar	*ASTM D1500	<b>L4.5</b>	5.0	L5.5
Pensky-Martens Flash Point	°C	*PMCC Calculated	<b>61.9</b>	64	65

#### SULFUR CONTENT

	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	<b>0</b>	0	5
Sulfur (UVF)	ppm	ASTM D5453	<b>9</b>	10	10

#### DISTILLATION

	method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	<b>173</b>	166	166
5% Distillation Point	°C	ASTM D86	<b>196</b>	191	191
10% Distill Point	°C	ASTM D86	<b>206</b>	203	203
15% Distillation Point	°C	ASTM D86	<b>213</b>	211	212
20% Distill Point	°C	ASTM D86	<b>221</b>	219	219
30% Distill Point	°C	ASTM D86	<b>236</b>	233	233
40% Distill Point	°C	ASTM D86	<b>249</b>	247	246
50% Distill Point	°C	ASTM D86	<b>262</b>	261	260
60% Distill Point	°C	ASTM D86	<b>276</b>	275	274
70% Distill Point	°C	ASTM D86	<b>290</b>	289	289
80% Distill Point	°C	ASTM D86	<b>306</b>	306	305
85% Distillation Point	°C	ASTM D86	<b>317</b>	315	315
90% Distill Point	°C	ASTM D86	<b>327</b>	326	326
95% Distillation Point	°C	ASTM D86	<b>344</b>	343	343
Final Boiling Point	°C	ASTM D86	<b>357</b>	353	352
Distillation Residue	%	ASTM D86	---	1.4	1.4
Distillation Loss	%	ASTM D86	---	0.7	0.8

#### IGNITION QUALITY






	method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.7	<b>36</b>	36.6	36.6
Cetane Index	ASTM D4737	<40.0	<b>48</b>	47.9	48.0

#### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<b>0</b>	1	2
Sodium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Potassium	ppm	ASTM D5185m	<b>0</b>	0	10
Water	%	ASTM D6304	<b>0.004</b>	0.005	0.004
ppm Water	ppm	ASTM D6304	<b>45</b>	56.2	40
% Gasoline	%	*In-House	<b>0.0</b>	0.0	0.0
% Biodiesel	%	*In-House	<b>1.4</b>	0.0	0.4





# FUEL REPORT





FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 43911	---	---
Particles >6µm	ASTM D7647	>640	▲ 20738	---	---
Particles >14µm	ASTM D7647	>80	▲ 1603	---	---
Particles >21µm	ASTM D7647	>20	▲ 237	---	---
Particles >38µm	ASTM D7647	>4	▲ 8	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 23/22/18	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	<1
Nickel	ppm	ASTM D5185m <0.1	0	0	0
Lead	ppm	ASTM D5185m <0.1	0	0	0
Vanadium	ppm	ASTM D5185m <0.1	0	0	0
Iron	ppm	ASTM D5185m <0.1	0	0	<1
Calcium	ppm	ASTM D5185m <0.1	1	0	0
Magnesium	ppm	ASTM D5185m <0.1	0	0	0
Phosphorus	ppm	ASTM D5185m <0.1	<1	0	0
Zinc	ppm	ASTM D5185m <0.1	0	0	0

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					







no image

no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0949581 **Received** : 14 Jun 2024  
**Lab Number** : 06211170 **Tested** : 20 Jun 2024  
**Unique Number** : 11084034 **Diagnosed** : 20 Jun 2024 - Elizabeth Valachovic  
**Test Package** : DF-2 ( Additional Tests: Fuel, Screen )

**COUCH OIL COMPANY**  
 2907 HILLSBOROUGH RD  
 DURHAM, NC  
 US 27705  
 Contact: JESSE BROWN  
 jesse@couchoilcompany.com  
 T: (919)285-5408  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)