

FUEL REPORT

Sample Rating Trend

NORMAL

Area **CAROLINA MEADOWS CLUB CENTER**

Diesel Fuel Fluid

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the fuel.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

| | | | | | | V |
|----------------------------|--------|------------------|------------|-------------|----------|----------|
|) (GAL) | | | Jun2024 | | | |
| SAMPLE INFORM | IATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | WC06211176 | | |
| Sample Date | | Client Info | | 16 Jun 2024 | | |
| Machine Age | mls | Client Info | | 0 | | |
| Sample Status | | | | NORMAL | | |
| PHYSICAL PROP | ERTIES | method | limit/base | current | history1 | history2 |
| Fuel Color | text | *Visual Screen | Yllow | Red | | |
| ASTM Color | scalar | *ASTM D1500 | | L4.0 | | |
| Pensky-Martens Flash Point | °C | *PMCC Calculated | 52 | 61.5 | | |
| SULFUR CONTER | ١T | method | limit/base | current | history1 | history2 |
| Sulfur | ppm | ASTM D5185m | 10 | 0 | | |
| Sulfur (UVF) | ppm | ASTM D5453 | | 330 | | |
| DISTILLATION | | method | limit/base | current | history1 | history2 |
| Initial Boiling Point | °C | ASTM D86 | 165 | 173 | | |
| 5% Distillation Point | °C | ASTM D86 | | 196 | | |
| 10% Distill Point | °C | ASTM D86 | 201 | 206 | | |
| 15% Distillation Point | °C | ASTM D86 | | 214 | | |
| 20% Distill Point | °C | ASTM D86 | 216 | 221 | | |
| 30% Distill Point | °C | ASTM D86 | 230 | 236 | | |
| 40% Distill Point | °C | ASTM D86 | 243 | 249 | | |
| 50% Distill Point | °C | ASTM D86 | 255 | 262 | | |
| 60% Distill Point | °C | ASTM D86 | 267 | 276 | | |
| 70% Distill Point | °C | ASTM D86 | 280 | 290 | | |
| 80% Distill Point | °C | ASTM D86 | 295 | 305 | | |
| 85% Distillation Point | °C | ASTM D86 | 0.15 | 315 | | |
| 90% Distill Point | °C | ASTM D86 | 310 | 326 | | |
| 95% Distillation Point | °C | ASTM D86 | 0.4.1 | 343 | | |
| Final Boiling Point | °C | ASTM D86 | | 357 | | |
| IGNITION QUALI | ΓY | method | limit/base | current | history1 | history2 |
| API Gravity | | ASTM D7777 | 37.7 | 35 | | |
| Cetane Index | | ASTM D4737 | <40.0 | 47 | | |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | <1.0 | 0 | | |
| Sodium | ppm | ASTM D5185m | <0.1 | <1 | | |
| Potassium | ppm | ASTM D5185m | <0.1 | 0 | | |
| Water | % | ASTM D6304 | < 0.05 | 0.005 | | |
| ppm Water | ppm | ASTM D6304 | <500 | 56 | | |
| % Gasoline | % | *In-House | <0.50 | 0.0 | | |
| % Biodiesel | % | *In-House | <20.0 | 0.0 | | |



FUEL REPORT



| FLUID CLEANLIN | ESS | method | limit/base | current | history1 | history2 |
|----------------------|-----|--------------|---|---------------------------------|------------------|----------|
| Particles >4µm | | ASTM D7647 | >2500 | 1127 | | |
| Particles >6µm | | ASTM D7647 | >640 | 181 | | |
| Particles >14µm | | ASTM D7647 | >80 | 7 | | |
| Particles >21µm | | ASTM D7647 | >20 | 2 | | |
| Particles >38µm | | ASTM D7647 | >4 | 0 | | |
| Particles >71µm | | ASTM D7647 | >3 | 0 | | |
| Dil Cleanliness | | ISO 4406 (c) | >18/16/13 | 17/15/10 | | |
| HEAVY METALS | | method | limit/base | current | history1 | history2 |
| Aluminum | ppm | ASTM D5185m | <0.1 | 0 | | |
| lickel | ppm | ASTM D5185m | <0.1 | 0 | | |
| ead | ppm | ASTM D5185m | <0.1 | 0 | | |
| /anadium | ppm | ASTM D5185m | <0.1 | 0 | | |
| ron | ppm | ASTM D5185m | <0.1 | <1 | | |
| Calcium | ppm | ASTM D5185m | <0.1 | 0 | | |
| lagnesium | ppm | ASTM D5185m | <0.1 | 0 | | |
| hosphorus | ppm | ASTM D5185m | <0.1 | 0 | | |
| linc | ppm | ASTM D5185m | <0.1 | 0 | | |
| SAMPLE IMAGES | 6 | method | limit/base | current | history1 | history2 |
| Color | | | | | no image | no image |
| Bottom | | | | | no image | no image |
| GRAPHS | | | | | | |
| Fuel Distillation Cu | | | 550 500 450 400 | Base b7gjung GCD Spectrur | ns Flash Point (| |
| | | | (Vd) 350 300 250 200 150 100 50 | | | |

: 14 Jun 2024

: 20 Jun 2024

: 20 Jun 2024 - Elizabeth Valachovic

Received

Diagnosed

Tested



g 250

200

150

Test Package : DF-2 (Additional Tests: Fuel, Screen) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Lab Number : 06211176

Unique Number : 11084040

Laboratory

Sample No.

: WC06211176

Contact/Location: JESSE BROWN - COUDUR

F:

DURHAM, NC US 27705

T: (919)285-5408

2907 HILLSBOROUGH RD

Contact: JESSE BROWN

jesse@couchoilcompany.com

Report Id: COUDUR [WUSCAR] 06211176 (Generated: 06/22/2024 04:52:22) Rev: 1