

### **OIL ANALYSIS REPORT**

Sample Rating Trend

NORMAL

# KAESER SFC 75S 4620239 (S/N 1020)

Component Compressor

Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129868	KC129315	KC05964631
Sample Date		Client Info		16 Jun 2024	27 Mar 2024	19 Sep 2023
Machine Age	hrs	Client Info		63509	62526	60287
Oil Age	hrs	Client Info		3000	2500	0
Oil Changed		Client Info		Not Changd	Not Changd	N/A
Sample Status				NORMAL	ATTENTION	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	3	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	3	2	5
Tin	ppm	ASTM D5185m	>10	0	<1	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	nom	ASTM D5185m		0	0	0
Barium	ppm ppm	ASTM D5185m	90	10	36	<1
Molybdenum		ASTM D5185m	90	0	0	0
Manganese	ppm ppm	ASTM D5185m		۰ <1	0	0
Magnesium		ASTM D5185m	90	39	58	17
Calcium	ppm ppm	ASTM D5185m	2	0	5	2
Phosphorus		ASTM D5185m	2	۰ <1	<1	2
Zinc	ppm ppm	ASTM D5185m		15	8	18
		ASTIVI DJIOJIII		15	0	10
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	0
Sodium	ppm	ASTM D5185m		18	23	5
Potassium	ppm	ASTM D5185m		2	6	0
Water	%	ASTM D6304		0.024	0.047	0.003
ppm Water	ppm	ASTM D6304	>500	243	474	39.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1043	9820	5251
Particles >6µm		ASTM D7647	>1300	319	1704	1392
Particles >14µm		ASTM D7647	>80	18	66	80
Particles >21µm		ASTM D7647	>20	3	18	21
Particles >38µm		ASTM D7647	>4	0	1	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/15/11	0/18/13	0/18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.32	0.42	0.38





## **OIL ANALYSIS REPORT**












VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	45.6	45.2	44.7
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						

Bottom



To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: TRITAR [WUSCAR] 06212381 (Generated: 06/21/2024 21:05:33) Rev: 1

Certificate 12367

Contact/Location: SERVICE MANAGER ? - TRITAR

Page 2 of 2

T:

F: