


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# KAESER CSD 75T 6803269 (S/N 1003)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- QTS)

Ν		

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2020	Jul2021	Jul2022 Jun2023	Jun 2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC131656	KC120629	KC103314
Sample Date		Client Info		16 Jun 2024	12 Jun 2023	22 Jul 2022
Machine Age	hrs	Client Info		4380	3412	2714
Oil Age	hrs	Client Info		1000	0	2000
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	1
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	1	1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	4	2	2
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	17	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	90	57	62	54
Calcium	ppm	ASTM D5185m	2	<1	0	0
Phosphorus	ppm	ASTM D5185m		1	0	4
Zinc	ppm	ASTM D5185m		7	0	5
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		15	19	16
Potassium	ppm	ASTM D5185m	>20	3	6	7
Water	%	ASTM D6304	>0.05	0.029	0.028	0.035
ppm Water	ppm	ASTM D6304	>500	299	286.4	350.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1418	880	634
Particles >6µm		ASTM D7647	>1300	568	232	222
Particles >14μm		ASTM D7647	>80	71	24	30
Particles >21µm		ASTM D7647	>20	20	7	6
Particles >38μm		ASTM D7647	>4	1	0	1
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/13	17/15/12	16/15/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.38	0.40	0.37



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No. Lab Number

Unique Number : 11085246 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KC131656 : 06212382

Received : 17 Jun 2024 **Tested** Diagnosed

: 21 Jun 2024 : 21 Jun 2024 - Jonathan Hester

**ACCUTREX PRODUCTS** 112 SOUTHPOINTE BLVD CANONSBURG, PA US 15317

Contact: MIKE GRAHAM

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T: (724)746-4300 F: