

# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SM 7.5 8855743 (S/N 1373)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Apr2024	May2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC130502	KC124436	
Sample Date		Client Info		14 May 2024	25 Apr 2024	
Machine Age	hrs	Client Info		9716	8416	
Oil Age	hrs	Client Info		6000	0	
Oil Changed		Client Info		Changed	N/A	
Sample Status				NORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	<1	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	<1	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	2	
Lead	ppm	ASTM D5185m	>10	0	<1	
Copper	ppm	ASTM D5185m	>50	10	10	
Tin	ppm	ASTM D5185m	>10	0	<1	
Vanadium	ppm	ASTM D5185m		<1	<1	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	0	<1	
Molybdenum	ppm	ASTM D5185m		0	<1	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m	90	2	18	
Calcium	ppm	ASTM D5185m	2	0	3	
Phosphorus	ppm	ASTM D5185m		2	2	
Zinc	ppm	ASTM D5185m		5	8	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	3	
Sodium	ppm	ASTM D5185m		2	5	
Potassium	ppm	ASTM D5185m	>20	0	2	
Water	%	ASTM D6304	>0.05	0.005	0.006	
ppm Water	ppm	ASTM D6304	>500	59	69	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		2301	25835	
Particles >6µm		ASTM D7647	>1300	779	<u>▲</u> 6661	
Particles >14µm		ASTM D7647	>80	50	<u></u> 510	
Particles >21µm		ASTM D7647	>20	7	<u>120</u>	
Particles >38µm		ASTM D7647	>4	1	4	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/17/13	<u>^</u> 22/20/16	
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
A : 1 N	1/011/	AOTH Doors	0.4		0.01	

Acid Number (AN)


mg KOH/g ASTM D8045 0.4

0.24

0.31



## **OIL ANALYSIS REPORT**







Certificate 12367

Laboratory Sample No.

: KC130502 Lab Number : 06212403 Unique Number : 11085267 Test Package : IND 2

Received : 17 Jun 2024 **Tested** : 19 Jun 2024 Diagnosed

: 19 Jun 2024 - Don Baldridge

**AXEM PRECISION** 1895 AIRPORT EXCHANGE ERLANGER, KY

US 41018 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: