


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

6533971 (S/N 1175)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				555255		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018368	KCPA009271	KCP55215
Sample Date		Client Info		12 Jun 2024	15 Dec 2023	24 May 2023
Machine Age	hrs	Client Info		32463	28946	25162
Oil Age	hrs	Client Info		0	0	1
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	2	1
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	81	60	51
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	100	80	73	63
Calcium	ppm	ASTM D5185m	0	2	2	5
Phosphorus	ppm	ASTM D5185m	0	1	1	5
Zinc	ppm	ASTM D5185m	0	4	3	0
Sulfur	ppm	ASTM D5185m	23500	21537	18141	19895
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	<1	<1
Sodium	ppm	ASTM D5185m		32	28	41
Potassium	ppm	ASTM D5185m	>20	4	2	<1
Water	%	ASTM D6304	>0.05	0.029	0.023	0.021
ppm Water	ppm	ASTM D6304	>500	291	234	216.6
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		1688	1227	1108
Particles >6µm		ASTM D7647	>1300	481	393	324
Particles >14μm		ASTM D7647	>80	47	49	41
Particles >21μm		ASTM D7647	>20	10	14	11
Particles >38μm		ASTM D7647	>4	1	1	1
Particles >71μm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/13	17/16/13	17/16/13
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate 12367

Sample No. Lab Number

: KCPA018368 : 06212411 Unique Number : 11085275

Received : 17 Jun 2024 **Tested** : 19 Jun 2024

Diagnosed : 19 Jun 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Contact: PROPERTY property@150hooper.org T: Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F:

Report Id: 150SAN [WUSCAR] 06212411 (Generated: 06/21/2024 20:51:37) Rev: 1

Contact/Location: PROPERTY ? - 150SAN

150 HOOPER ST

US 94107

SAN FRANCISCO, CA