




PROBLEM SUMMARY


Area
Milliken
 Machine Id
INGERSOLL RAND EE4347U19082 - MILLIKEN
 Component
Compressor
 Fluid
INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

Sample Rating Trend




COMPONENT CONDITION SUMMARY

▲ Non-ferrous Metals



● Particle Trend



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	SEVERE	SEVERE
Tin	ppm	ASTM D5185m	>15	▲ 357	▲ 278	▲ 233

Customer Id: AIRALLPA
 Sample No.: APCI2320830
 Lab Number: 06212477
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearscheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearscheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Inspect Wear Source	---	---	?	We advise that you inspect for the source(s) of wear.
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

WEAR



05 Mar 2024 Diag: Don Baldrige

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. The tin level is severe. All other component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.

[view report](#)



WEAR



05 Dec 2023 Diag: Jonathan Hester

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. The tin level is severe. All other component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid.

[view report](#)



WEAR



18 Sep 2023 Diag: Don Baldrige

The oil is near the end of its useful service life, recommend schedule an oil change. We recommend an early resample to monitor this condition. The tin level is severe. All other component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.


[view report](#)





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Area
Milliken
 Machine Id
INGERSOLL RAND EE4347U19082 - MILLIKEN
 Component
Compressor
 Fluid
INGERSOLL-RAND SSR ULTRA COOLANT (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We advise that you inspect for the source(s) of wear. We recommend an early resample to monitor this condition.

Wear

The tin level is severe.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		APCI2320830	APCI2320834	APCI2320833
Sample Date	Client Info		10 Jun 2024	05 Mar 2024	05 Dec 2023
Machine Age	hrs	Client Info	0	37456	33169
Oil Age	hrs	Client Info	2000	2000	4000
Oil Changed	Client Info		Changed	N/A	Not Changd
Sample Status			SEVERE	SEVERE	SEVERE

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	1	0	2
Chromium	ppm	ASTM D5185m >10	0	0	<1
Nickel	ppm	ASTM D5185m	0	0	<1
Titanium	ppm	ASTM D5185m	<1	0	<1
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	0	2
Lead	ppm	ASTM D5185m >25	0	0	<1
Copper	ppm	ASTM D5185m >50	1	0	<1
Tin	ppm	ASTM D5185m >15	▲ 357	▲ 278	▲ 233
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	<1

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	0	0	0
Barium	ppm	ASTM D5185m 500	430	536	590
Molybdenum	ppm	ASTM D5185m 0	0	0	<1
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m 0	4	1	<1
Calcium	ppm	ASTM D5185m 0	8	4	4
Phosphorus	ppm	ASTM D5185m 20	3	0	23
Zinc	ppm	ASTM D5185m 0	10	0	0
Sulfur	ppm	ASTM D5185m 200	391	324	217

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	1	<1	2
Sodium	ppm	ASTM D5185m	53	51	52
Potassium	ppm	ASTM D5185m >20	8	6	7
Water	%	ASTM D6304 >0.1	0.309	0.283	0.222
ppm Water	ppm	ASTM D6304 >1000	3098	2839	2227

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	● 15701	5835	● 15505
Particles >6µm	ASTM D7647	>2500	● 4204	2045	● 2628
Particles >14µm	ASTM D7647	>320	95	154	146
Particles >21µm	ASTM D7647	>80	15	36	46
Particles >38µm	ASTM D7647	>20	1	1	4
Particles >71µm	ASTM D7647	>4	0	0	1
Oil Cleanliness	ISO 4406 (c)	>20/18/15	● 21/19/14	20/18/14	● 21/19/14

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.17	0.787	0.51




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	49.4	56.4	54.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : APC12320830

Lab Number : 06212477

Unique Number : 11085341

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Received : 17 Jun 2024

Tested : 20 Jun 2024

Diagnosed : 20 Jun 2024 - Jonathan Hester

AIR PRODUCTS AND CHEMICALS INC - ALLENTOWN

7201 HAMILTON BLVD

ALLENTOWN, PA

US 18195

Contact: MICHAEL PROTZEK

protzema@airproducts.com

T:

F: