


PROBLEM SUMMARY

Sample Rating Trend




Machine Id CR3312

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you follow the water drain-off procedure for this component. We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system. We recommend an early resample to monitor this condition.

PROBLEMATIC	TEST RI	ESULTS				
Sample Status				SEVERE	ABNORMAL	NORMAL
Water	%	ASTM D6304	< 0.05	△ 0.072	0.011	0.003
ppm Water	ppm	ASTM D6304	< 500	730	119.8	28.7

Customer Id: BUCGRA Sample No.: WC0935910 Lab Number: 06213052 Test Package: CONST



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system.		
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component.		
Resample			?	We recommend an early resample to monitor this condition.		
Contact Required			?	We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system.		

HISTORICAL DIAGNOSIS

17 Oct 2023 Diag: Jonathan Hester

SEDIMENT



This is a baseline read-out on the submitted sample. We recommend you service the filters on this component.All metal levels are normal indicating no corrosion in the system. There is a moderate amount of visible silt present in the sample. The water content is negligible. The condition of the fuel is acceptable for the time in service.



NORMAL



14 Jun 2023 Diag: Jonathan Hester

This is a baseline read-out on the submitted sample. No corrective action is recommended at this time. All metal levels are normal indicating no corrosion in the system. The water content is negligible. There is no indication of any contamination in the fuel. The condition of the fuel is acceptable for the time in service.



NORMAL



14 Jan 2023 Diag: Doug Bogart


This is a baseline read-out on the submitted sample. All metal levels are normal indicating no corrosion in the system. The water content is negligible. There is no indication of any contamination in the fuel. The condition of the fuel is acceptable for the time in service.





FUEL REPORT

Sample Rating Trend



Machine Id CR3312
Component

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component. We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system. We recommend an early resample to monitor this condition.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Excessive free water present. There is a light concentration of suspended water present in the fuel. There is a high amount of visible silt and debris present in the sample. Possible bacteria or fungus (yeast and/or mold) indicated in the sample.


Fuel Condition


The fuel is no longer serviceable due to the presence of contaminants.


1) (GAL)		ryicott ryi		Jun2022 Jan2023 Jun2023 Oct20		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0935910	WC0833266	WC0810370
Sample Date		Client Info		13 Jun 2024	17 Oct 2023	14 Jun 2023
Machine Age	hrs	Client Info		11130	9974	9364
Sample Status				SEVERE	ABNORMAL	NORMAL
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	3.0	2.28	2.57	2.69
SULFUR CONTER	٧T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0	0	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1	0	<1
Sodium	ppm	ASTM D5185m	<0.1	2	0	2
Potassium	ppm	ASTM D5185m	< 0.1	0	2	0
Water	%	ASTM D6304	< 0.05	△ 0.072	0.011	0.003
ppm Water	ppm	ASTM D6304	< 500	730	119.8	28.7
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	< 0.1	0	2	<1
Nickel	ppm	ASTM D5185m	<0.1	0	0	<1
Lead	ppm	ASTM D5185m	< 0.1	0	<1	<1
Vanadium	ppm	ASTM D5185m	<0.1	0	0	<1
Iron	ppm	ASTM D5185m	< 0.1	0	<1	<1
Calcium	ppm	ASTM D5185m	<0.1	0	0	<1
Magnesium	ppm	ASTM D5185m	< 0.1	0	0	5
Phosphorus	ppm	ASTM D5185m	<0.1	2	1	0
Zinc	ppm	ASTM D5185m	<0.1	<1	0	4
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color				CR. 30		
Bottom						




FUEL REPORT







GRAPHS





Laboratory

Sample No. : WC0935910 Lab Number : 06213052 Unique Number : 11085916

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 17 Jun 2024 **Tested** : 21 Jun 2024 Diagnosed

: 21 Jun 2024 - Doug Bogart

BUCKNER HEAVY LIFT 4732 NC 54 EAST GRAHAM, NC US 27253-9215 Contact: MICHAEL LAWSON

Test Package : CONST (Additional Tests: Bacteria, KF) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

michaell@bucknercompanies.com T: (336)376-8888

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (336)376-4090 Contact/Location: MICHAEL LAWSON - BUCGRA