


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

8161164 (S/N 1036)Component Compressor

{not provided} (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Jun 2024		,
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA018284		
Sample Date		Client Info		12 Jun 2024		
Machine Age	hrs	Client Info		15984		
Oil Age	hrs	Client Info		15984		
Oil Changed		Client Info		Changed		
Sample Status				ABNORMAL		
			11 11 11		1111	1111
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	5		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m	>3	<1		
Titanium	ppm	ASTM D5185m	>3	<1		
Silver	ppm	ASTM D5185m	>2	<1		
Aluminum	ppm	ASTM D5185m	>10	<u>^</u> 27		
Lead	ppm	ASTM D5185m	>10	<1		
Copper	ppm	ASTM D5185m	>50	2		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		<1		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		1		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		206		
Zinc	ppm	ASTM D5185m		204		
Sulfur	ppm	ASTM D5185m		1709		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	2		
Water	%	ASTM D6304	>0.05	0.003		
ppm Water	ppm	ASTM D6304	>500	37		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		6336		
Particles >6µm		ASTM D7647	>1300	2493		
Particles >14μm		ASTM D7647	>80	<u>▲</u> 212		
Particles >21µm		ASTM D7647	>20	<u>^</u> 24		
Particles >38µm		ASTM D7647	>4	1		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/15		
	TION	()			hictory.	higt-w.O
FLUID DEGRADA	HON	method	limit/base	current	history1	history2


Acid Number (AN)

mg KOH/g ASTM D8045

0.59



OIL ANALYSIS REPORT





Certificate 12367

Laboratory Sample No.

: KCPA018284 Lab Number : 06213487 Unique Number : 11086351

Received : 18 Jun 2024 **Tested**

: 19 Jun 2024 Diagnosed

: 20 Jun 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: Service Manager - SELVIS

VISTA, CA

US 92081

T:

F:

2390 OAK RIDGE WAY

Contact: Service Manager