


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id **LINE 10 EXTRUDER 1**

Component **Gearbox**

MOBIL DTE OIL EXTRA HEAVY (9 GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0955097	WC0893628	WC0838519
Sample Date		Client Info		14 Jun 2024	27 Dec 2023	14 Jul 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>0.2	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	18	15	15
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	<1	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	0	0	<1
Lead	ppm	ASTM D5185m	>100	0	0	<1
Copper	ppm	ASTM D5185m	>200	5	6	6
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	3
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	3	2
Calcium	ppm	ASTM D5185m		123	116	104
Phosphorus	ppm	ASTM D5185m		409	434	393
Zinc	ppm	ASTM D5185m		540	569	523
Sulfur	ppm	ASTM D5185m		10629	9468	9833
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	1	2	1
Sodium	ppm	ASTM D5185m		2	3	0
Potassium	ppm	ASTM D5185m	>20	0	1	<1
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.80	0.72	0.84




135 130 125


OIL ANALYSIS REPORT




VICLIAL		and the section	1114/1		late kan med	h'-10
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	146	147	147	148
SAMPLE IMAGES		method	limit/base	current	history1	history2
			_			


Color





















Certificate 12367

Laboratory Sample No. Lab Number : 06213630 Unique Number : 11086494 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0955097

Received **Tested** Diagnosed

: 18 Jun 2024 : 20 Jun 2024

: 20 Jun 2024 - Sean Felton

Altium Packaging - WEST CHICAGO - DUPAGE - Plant 1123A 1300 NORTHWEST AVE WEST CHICAGO, IL

US 60185 Contact: DALE HARRISON

dale.harrison@altiumpkg.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: CONSTR [WUSCAR] 06213630 (Generated: 06/21/2024 18:16:31) Rev: 1

Contact/Location: DALE HARRISON - CONSTR

T: x:

F: x: