




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Area

**EL SAUZ [200007686]**

Machine Id

**M03-34WEA90071 (S/N W-122935)**

Component

**Wind Turbine Gearbox**

Fluid

**FUCHS RENOLIN UNISYN CLP 320 (--- LTR)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>NX015080</b>	NX012703	NX014600
Sample Date	Client Info		<b>05 May 2024</b>	13 Feb 2024	09 Dec 2023
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2	
PQ	ASTM D8184	>40	<b>19</b>	11	13	
Iron	ppm	ASTM D5185m	>55	<b>44</b>	41	9
Chromium	ppm	ASTM D5185m	>2	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	<1	0
Titanium	ppm	ASTM D5185m	>10	<b>0</b>	0	0
Silver	ppm	ASTM D5185m		<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>15	<b>&lt;1</b>	2	0
Lead	ppm	ASTM D5185m	>3	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>7	<b>1</b>	<1	<1
Tin	ppm	ASTM D5185m	>3	<b>&lt;1</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>2</b>	2	2
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>0</b>	0	0
Manganese	ppm	ASTM D5185m		<b>1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>2</b>	<1	0
Calcium	ppm	ASTM D5185m		<b>12</b>	17	19
Phosphorus	ppm	ASTM D5185m		<b>218</b>	196	216
Zinc	ppm	ASTM D5185m		<b>19</b>	17	0
Sulfur	ppm	ASTM D5185m		<b>5928</b>	4783	5039

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>35	<b>7</b>	8	4
Sodium	ppm	ASTM D5185m		<b>3</b>	2	1
Potassium	ppm	ASTM D5185m	>20	<b>4</b>	2	<1
Water	%	ASTM D6304	>0.02	<b>0.008</b>	0.002	0.010
ppm Water	ppm	ASTM D6304	>200	<b>89</b>	19	108

## FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>10766</b>	31596	35707
Particles >6µm	ASTM D7647	>320	<b>854</b>	9641	1483
Particles >14µm	ASTM D7647	>40	<b>6</b>	579	102
Particles >21µm	ASTM D7647	>10	<b>1</b>	119	29
Particles >38µm	ASTM D7647	>3	<b>0</b>	2	1
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/15/12	<b>21/17/10</b>	22/20/16	22/18/14

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.6	<b>0.35</b>	0.34	0.36




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.02	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 320	331	332	314

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513

**Sample No.** : NX015080

**Lab Number** : 06214011

**Unique Number** : 11086875

**Test Package** : IND 2 ( Additional Tests: KF, PQ, PrtCount )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**Received** : 18 Jun 2024

**Tested** : 20 Jun 2024

**Diagnosed** : 20 Jun 2024 - Don Baldrige

**NORDEX USA - Chicago**

300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL

US 60606

Contact: DEVIN LINEHAN

DLinehan@nordex-online.com

T: (312)386-4124

F: (312)386-7102