




# PROBLEM SUMMARY

Machine Id  
**BUSCH 8600 VA S1 (S/N 400501-1)**  
 Component  
**Pump**  
 Fluid  
**USPI VAC 100 (--- GAL)**

Sample Rating Trend




WATER



## COMPONENT CONDITION SUMMARY

▲ Water (KF)



## RECOMMENDATION

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	ABNORMAL	ABNORMAL
Water	%	ASTM D6304	>.1	▲ 4.74	▲ 0.930	▲ 0.626
ppm Water	ppm	ASTM D6304	>1000	▲ 47400	▲ 9302	▲ 6260
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Emulsified Water	scalar	*Visual	>.1	▲ 0.2%	NEG	▲ 0.2%

Customer Id: IBPEMP01  
 Sample No.: USPM37781  
 Lab Number: 06214053  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Doug Bogart +1 (800)237-1369 x4016  
[dougb@wearcheckusa.com](mailto:dougb@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

**RECOMMENDED ACTIONS**

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.
Resample	---	---	?	We recommend an early resample to monitor this condition.
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

**HISTORICAL DIAGNOSIS**

**WATER**



**29 Jan 2024 Diag: Doug Bogart**

We advise an early resample to confirm this situation. Insufficient sample was received to conduct all the routine laboratory tests. All component wear rates are normal. There is a high concentration of water present in the oil. The condition of the oil's additive package appears suitable for further service.

[view report](#)



**WATER**



**06 Sep 2022 Diag: Doug Bogart**

We advise that you follow the water drain-off procedure for this component and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles and water present in this sample. All component wear rates are normal. Appearance is hazy. High concentration of visible dirt/debris present in the oil. There is a moderate concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid.

[view report](#)



**WATER**



**11 Nov 2021 Diag: Doug Bogart**

We advise that you follow the water drain-off procedure for this component and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. There is a moderate concentration of water present in the oil. Free water present. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id  
**BUSCH 8600 VA S1 (S/N 400501-1)**  
 Component  
**Pump**  
 Fluid  
**USPI VAC 100 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample.

### Wear

All component wear rates are normal.

### ▲ Contamination

Appearance is unacceptable. There is a high concentration of water present in the oil. There is a moderate amount of visible silt present in the sample.

### Fluid Condition

The AN level is acceptable for this fluid. The oil is no longer serviceable due to the presence of contaminants.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>USPM37781</b>	USPM30860	USPR000718
Sample Date	Client Info		<b>01 Jun 2024</b>	29 Jan 2024	06 Sep 2022
Machine Age	hrs	Client Info	<b>0</b>	0	0
Oil Age	hrs	Client Info	<b>0</b>	0	0
Oil Changed	Client Info		<b>N/A</b>	N/A	N/A
Sample Status			<b>SEVERE</b>	ABNORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >90	<b>7</b>	<1	3
Chromium	ppm	ASTM D5185m >5	<b>0</b>	<1	0
Nickel	ppm	ASTM D5185m >5	<b>1</b>	0	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m >3	<b>&lt;1</b>	0	<1
Aluminum	ppm	ASTM D5185m >7	<b>2</b>	2	1
Lead	ppm	ASTM D5185m >12	<b>&lt;1</b>	0	<1
Copper	ppm	ASTM D5185m >30	<b>&lt;1</b>	<1	<1
Tin	ppm	ASTM D5185m >9	<b>3</b>	<1	<1
Antimony	ppm	ASTM D5185m	<b>---</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>7</b>	0	1
Barium	ppm	ASTM D5185m 0	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	<1	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	0	<1
Magnesium	ppm	ASTM D5185m 0	<b>3</b>	0	<1
Calcium	ppm	ASTM D5185m 0	<b>6</b>	<1	2
Phosphorus	ppm	ASTM D5185m 1800	<b>1619</b>	1391	1540
Zinc	ppm	ASTM D5185m 0	<b>6</b>	0	<1
Sulfur	ppm	ASTM D5185m 0	<b>63</b>	0	31

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >60	<b>3</b>	1	2
Sodium	ppm	ASTM D5185m	<b>26</b>	0	0
Potassium	ppm	ASTM D5185m >20	<b>5</b>	1	1
Water	%	ASTM D6304 >.1	<b>▲ 4.74</b>	▲ 0.930	▲ 0.626
ppm Water	ppm	ASTM D6304 >1000	<b>▲ 47400</b>	▲ 9302	▲ 6260

## FLUID CLEANLINESS




	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	<b>---</b>	---	---
Particles >6µm	ASTM D7647	>1300	<b>---</b>	---	---
Particles >14µm	ASTM D7647	>160	<b>---</b>	---	---
Particles >21µm	ASTM D7647	>40	<b>---</b>	---	---
Particles >38µm	ASTM D7647	>10	<b>---</b>	---	---
Particles >71µm	ASTM D7647	>3	<b>---</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	<b>---</b>	---	---

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	<b>0.35</b>	---	0.37




# OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	▲ MODER	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ HEAVY
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	● HAZY	NORML	● HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	▲ 0.2%	NEG	▲ 0.2%
Free Water	scalar	*Visual	▲ NEG	NEG	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 91	107	96.8	95.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : USPM37781  
**Lab Number** : 06214053  
**Unique Number** : 11086917  
**Test Package** : IND 2  
**Received** : 18 Jun 2024  
**Tested** : 21 Jun 2024  
**Diagnosed** : 21 Jun 2024 - Doug Bogart

**TYSON-Emporia-USP**  
 2101 West Sixth  
 Emporia, KS  
 US 66801  
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (620)343-3640

F: (620)340-1253