




OIL ANALYSIS REPORT

Sample Rating Trend



DIRT



Area

CAST HOUSE/CRANES

Machine Id

89 WEST BRIDGE GEARBOX 1015-U89-3000

Component

Gearbox

Fluid

CITGO COMPOUND EP 320 (10 GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. We recommend an early resample to monitor this condition.

Wear

Gear wear is indicated.

Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.

Fluid Condition

The oil viscosity is lower than normal. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KFS0004614	KFS0005165	KFS0003342
Sample Date	Client Info	17 May 2024	19 Dec 2023	03 Jul 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	SEVERE	SEVERE

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.2	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
Iron	ppm ASTM D5185m >200	▲ 377	55	75
Chromium	ppm ASTM D5185m >15	2	<1	0
Nickel	ppm ASTM D5185m >15	<1	0	0
Titanium	ppm ASTM D5185m	<1	0	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >25	▲ 123	▲ 33	18
Lead	ppm ASTM D5185m >100	<1	0	0
Copper	ppm ASTM D5185m >200	7	<1	<1
Tin	ppm ASTM D5185m >25	0	0	0
Antimony	ppm ASTM D5185m >5	---	---	---
Vanadium	ppm ASTM D5185m	0	<1	<1
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	13	2	4
Barium	ppm ASTM D5185m	3	0	0
Molybdenum	ppm ASTM D5185m	4	<1	<1
Manganese	ppm ASTM D5185m	7	<1	2
Magnesium	ppm ASTM D5185m	24	2	12
Calcium	ppm ASTM D5185m	34	44	12
Phosphorus	ppm ASTM D5185m	196	100	376
Zinc	ppm ASTM D5185m	52	6	74
Sulfur	ppm ASTM D5185m	6276	1255	15416


CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	▲ 54	12	3
Sodium	ppm ASTM D5185m	3	29	<1
Potassium	ppm ASTM D5185m >20	4	5	0


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	▲ 254423	---	▲ 199287
Particles >6µm	ASTM D7647 >5000	▲ 187877	---	▲ 98028
Particles >14µm	ASTM D7647 >640	▲ 16675	---	▲ 3496
Particles >21µm	ASTM D7647 >160	▲ 2409	---	▲ 747
Particles >38µm	ASTM D7647 >40	▲ 51	---	17
Particles >71µm	ASTM D7647 >10	2	---	1
Oil Cleanliness	ISO 4406 (c) >21/19/16	▲ 25/25/21	---	▲ 25/24/19


▲ Particle Trend




▲ Silicon (ppm)




▲ Aluminum (ppm)



▲ Silicon (ppm)



▲ Aluminum (ppm)



FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.96	▲ 4.91	0.90

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	▲ MODER	MODER
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	▲ HEAVY	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	314	● 276	▲ 374	327

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------


Color

Bottom




GRAPHS


▲ Ferrous Alloys




Non-ferrous Metals




● Viscosity @ 40°C



▲ Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513

Sample No. : KFS0004614

Lab Number : 06214635

Unique Number : 11087499

Test Package : IND 2 (Additional Tests: PrtCount)

Received : 19 Jun 2024

Tested : 20 Jun 2024

Diagnosed : 21 Jun 2024 - Don Baldrige

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

CONSTELLIUM

4805 SECOND STREET

MUSCLE SHOALS, AL

US 35661

Contact: Randy Nichols

randall.nichols@constellium.com

T: (256)386-6956

F: