




# OIL ANALYSIS REPORT

Machine Id  
**Grand River CAT 5 GRRM05BE**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 9500 GAS ENGINE OIL 40 (90 GAL)**

Sample Rating Trend



**WEAR**



## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### ▲ Wear

The high ferrous density (PQ) index indicates that abnormal wear is occurring.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0934190</b>	WC0724871	WC0724870
Sample Date	Client Info		<b>17 Jun 2024</b>	21 Mar 2024	13 Mar 2024
Machine Age	hrs	Client Info	<b>76692</b>	76283	76283
Oil Age	hrs	Client Info	<b>488</b>	1400	1207
Oil Changed	Client Info		<b>Not Chngd</b>	Changed	Not Chngd
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Water	WC Method	>.11	<b>NEG</b>	NEG	NEG
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2
PQ	ASTM D8184	>21	<b>▲ 27</b>	---	---
Iron	ppm	ASTM D5185m	>15	<b>1</b>	4
Chromium	ppm	ASTM D5185m	>4	<b>0</b>	0
Nickel	ppm	ASTM D5185m		<b>0</b>	<1
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0
Silver	ppm	ASTM D5185m		<b>0</b>	0
Aluminum	ppm	ASTM D5185m	>6	<b>&lt;1</b>	1
Lead	ppm	ASTM D5185m	>9	<b>0</b>	2
Copper	ppm	ASTM D5185m	>6	<b>4</b>	3
Tin	ppm	ASTM D5185m	>4	<b>0</b>	2
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>12</b>	1
Barium	ppm	ASTM D5185m		<b>0</b>	0
Molybdenum	ppm	ASTM D5185m		<b>3</b>	2
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1
Magnesium	ppm	ASTM D5185m		<b>23</b>	12
Calcium	ppm	ASTM D5185m		<b>1832</b>	1904
Phosphorus	ppm	ASTM D5185m		<b>269</b>	286
Zinc	ppm	ASTM D5185m		<b>337</b>	350
Sulfur	ppm	ASTM D5185m		<b>1867</b>	1969

## CONTAMINANTS






	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>181	<b>25</b>	55
Sodium	ppm	ASTM D5185m	>21	<b>3</b>	4
Potassium	ppm	ASTM D5185m	>20	<b>2</b>	4

## INFRA-RED

	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>0</b>	0
Nitration	Abs/cm	*ASTM D7624		<b>6.9</b>	8.9
Sulfation	Abs/.1mm	*ASTM D7415		<b>15.7</b>	18.7



# OIL ANALYSIS REPORT












FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs./1mm	*ASTM D7414		<b>10.6</b>	16.9	15.7
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	<b>0.83</b>	1.88	1.80
Base Number (BN)	mg KOH/g	ASTM D2896	5.4	<b>4.22</b>	4.26	3.80

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML	NORML
Emulsified Water	scalar	*Visual	>.11	<b>NEG</b>	NEG	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	<b>13.7</b>	13.9	13.9

## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0934190 **Received** : 19 Jun 2024  
**Lab Number** : **06214918** **Tested** : 20 Jun 2024  
**Unique Number** : 11087782 **Diagnosed** : 21 Jun 2024 - Sean Felton  
**Test Package** : MOB 2 ( Additional Tests: PQ )

**EDL NA Recips-Grand River**  
 Grand River Powerstation, 8550 West Grand River Hwy  
 Grand Ledge, MI  
 US 48837  
 Contact: JAMES ALEXANDER  
 james.alexander@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)