

OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

ATLAS COPCO CAI335406 - SBI Component Compressor

Fluid

ISEL SERIES 2015-46 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		DFP0000036		
Sample Date		Client Info		17 Jun 2024		
Machine Age	hrs	Client Info		12748		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	0		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	0		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	0		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		122		
Zinc	ppm	ASTM D5185m		39		
Sulfur	ppm	ASTM D5185m		142		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	0		
Sodium	ppm	ASTM D5185m		2		
Potassium	ppm	ASTM D5185m	>20	3		
Water	%	ASTM D6304	>0.1	0.003		
ppm Water	ppm	ASTM D6304	>1000	35		
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	2679		
Particles >6µm		ASTM D7647	>2500	917		
Particles >14µm		ASTM D7647	>320	42		
Particles >21µm		ASTM D7647	>80	5		
Particles >38µm		ASTM D7647	>20	1		
Particles >71µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/13		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.15		



Water (ppm)

nber of particles (1

ŝ

particles (1)

for of

OIL ANALYSIS REPORT

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

NEG

NEG

45.8

Particle Count

Acid Number

491,52

122,88

30.72 7.68

1.92

480

120

31

(B/HO)

٩ 0.05 ال

0.00

Acid

(per 1 i

no image

no image

no image


no image

4406

:1999 Cle

14

5



Compressed Air Technology 1801 E. 39th Street North Sioux Falls, US 57104 Contact: KEN HURST khurst@dfpcompressedairtechnology.com T:

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Report Id: DFPSIO [WUSCAR] 06215795 (Generated: 06/22/2024 11:56:34) Rev: 1

Contact/Location: KEN HURST - DFPSIO

21µ

38L

Page 2 of 2

F: (605)332-0988