


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

FA9804 (S/N COOLING DRUM DROP)

Component **Gearbox**

MOBIL SHC 630 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

All component wear rates are normal.

Contamination

Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Oct2020	May2021 Oct2022	May2023 Nov2023	Apr2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0013170	USP0003676	USP246073
Sample Date		Client Info		29 Apr 2024	18 Nov 2023	21 May 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	0	0	<1
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	<1	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	0	0	0
Tin	ppm	ASTM D5185m	>25	<1	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		<1	0	<1
Calcium	ppm	ASTM D5185m		0	0	<1
Phosphorus	ppm	ASTM D5185m		411	338	402
Zinc	ppm	ASTM D5185m		13	3	<1
Sulfur	ppm	ASTM D5185m		23	32	106
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	17	14	16
Sodium	ppm	ASTM D5185m		1	<1	0
Potassium	ppm	ASTM D5185m	>20	3	0	<1
Water	%	ASTM D6304	>0.2	0.055	0.008	0.012
ppm Water	ppm	ASTM D6304	>2000	559	89.2	122.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000		4677	6393
Particles >6µm		ASTM D7647	>5000		2071	2628
Particles >14μm		ASTM D7647	>640		234	344
Particles >21µm		ASTM D7647	>160		43	55
Particles >38μm		ASTM D7647	>40		0	4
Particles >71μm		ASTM D7647	>10		0	1
Oil Cleanliness		ISO 4406 (c)	>21/19/16		19/18/15	20/19/16
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.29	0.36	0.41




OIL ANALYSIS REPORT











Color







GRAPHS













Certificate 12367

Laboratory Sample No. Lab Number : 06215805

Test Package : IND 2

: USP0013170 Unique Number : 11088669

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 20 Jun 2024 Tested : 24 Jun 2024

Diagnosed : 24 Jun 2024 - Doug Bogart

Contact: JASON GOEDKEN

Jason.Goedken@POET.COM T: (319)284-2621

POET BIO PROCESSING

1277 102ND ST

FAIRBANK, IA

US 50662

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)